

COMBINATION TABLES

Outdoor unit: MU2-Y 41M (DUAL)

MULTISplit

COOLING

OUTDOOR UNIT	INDOOR UNIT		COOLING CAPACITY [KW]		TOTAL COOLING CAPACITY [KW]			ABSORBED COOLING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)			
	A	B	A	B	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
MU2-Y 41M (1x1)	20M	—	2,30	—	1,23	2,00	2,90	0,30	0,62	0,77	1,30	2,68	3,34	3,25	—	—	—	—
	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	27M	—	2,50	—	1,23	2,50	3,20	0,30	0,77	0,96	1,30	3,34	4,18	3,25	—	—	—	—
	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	35M	—	3,50	—	1,23	3,50	3,90	0,30	1,08	1,35	1,30	4,68	5,85	3,25	—	—	—	—
	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
MU2-Y 41M (1x2)	53M	—	4,10	—	1,35	4,10	4,90	0,40	1,27	1,59	1,74	5,52	6,90	3,23	—	—	—	—
	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	20M	2,30	2,30	1,76	4,10	4,92	0,44	1,27	1,59	1,93	5,52	6,90	3,23	A+	6,80	4,10	211
	8.000	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	27M	1,79	2,31	1,76	4,10	4,92	0,44	1,27	1,59	1,93	5,52	6,90	3,23	A+	6,80	4,10	211
	8.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	35M	1,51	2,59	1,76	4,10	4,92	0,44	1,27	1,59	1,93	5,52	6,90	3,23	A+	6,80	4,10	211
	8.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	27M	27M	2,05	2,05	1,76	4,10	4,92	0,44	1,27	1,59	1,93	5,52	6,90	3,23	A+	6,80	4,10	211
	9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
MU2-Y 41M (1x2)	27M	35M	1,76	2,34	1,76	4,10	4,92	0,44	1,27	1,59	1,93	5,52	6,90	3,23	A+	6,80	4,10	211
	9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

Notes Pd = Pdesign CEA = Annual Energy Consumption

HEATING

OUTDOOR UNIT	INDOOR UNIT		HEATING CAPACITY [KW]		TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
	A	B	A	B	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
MU2-Y 41M (1x1)	20M	—	2,45	—	1,32	2,50	2,82	0,28	0,67	0,83	1,22	2,90	3,62	3,75	—	—	—	—
	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	27M	—	2,92	—	1,32	2,90	3,36	0,28	0,78	0,97	1,22	3,38	4,23	3,73	—	—	—	—
	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	35M	—	3,75	—	1,32	3,80	4,31	0,28	1,02	1,28	1,22	4,44	5,55	3,72	—	—	—	—
	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
MU2-Y 41M (1x2)	53M	—	4,40	—	1,45	4,40	5,24	0,38	1,19	1,48	1,65	5,16	6,45	3,71	—	—	—	—
	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	20M	2,20	2,20	1,89	4,40	5,28	0,42	1,19	1,48	1,80	5,16	6,45	3,71	A	4,00	3,70	1295
	8.000	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	27M	1,93	2,48	1,89	4,40	5,28	0,42	1,19	1,48	1,80	5,16	6,45	3,71	A	4,00	3,70	1295
	8.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	35M	1,62	2,78	1,89	4,40	5,28	0,42	1,19	1,48	1,80	5,16	6,45	3,71	A	4,00	3,70	1295
	8.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	27M	27M	2,20	2,20	1,89	4,40	5,28	0,42	1,19	1,48	1,80	5,16	6,45	3,71	A	4,00	3,70	1295
	9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
MU2-Y 41M (1x2)	27M	35M	1,89	2,51	1,89	4,40	5,28	0,42	1,19	1,48	1,80	5,16	6,45	3,71	A	4,00	3,70	1295
	9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

Notes Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 53M (DUAL)

COOLING	OUTDOOR UNIT	INDOOR UNIT		COOLING CAPACITY [KW]		TOTAL COOLING CAPACITY [KW]		POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)				
		A	B	A	B	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
MU2-Y 53M (1x1)		20M 8.000	—	2,30	—	1,43	2,00	2,90	0,35	0,60	0,75	1,52	2,60	3,24	3,35	—	—	—	—
		27M 9.000	—	2,50	—	1,43	2,50	3,20	0,35	0,75	0,93	1,52	3,24	4,06	3,35	—	—	—	—
		35M 12.000	—	3,50	—	1,43	3,50	3,90	0,35	1,08	1,29	1,52	4,68	5,62	3,25	—	—	—	—
		53M 18.000	—	5,00	—	1,64	5,00	5,51	0,45	1,55	1,89	1,96	6,73	8,20	3,23	—	—	—	—
MU2-Y 53M (1x2)		20M 8.000	20M 8.000	2,30	2,30	2,12	5,00	5,62	0,54	1,47	2,05	2,35	6,38	8,92	3,41	A+	6,10	5,30	304
		20M 8.000	27M 9.000	2,19	2,81	2,12	5,00	5,83	0,54	1,55	2,05	2,35	6,73	8,92	3,23	A+	6,10	5,30	304
		20M 8.000	35M 12.000	1,84	3,16	2,12	5,00	6,41	0,54	1,55	2,05	2,35	6,73	8,92	3,23	A+	6,10	5,30	304
		20M 8.000	53M 18.000	1,40	3,63	2,12	5,00	6,47	0,54	1,54	2,05	2,35	6,69	8,92	3,25	A+	6,10	5,30	304
		27M 9.000	27M 9.000	2,65	2,65	2,12	5,30	6,41	0,54	1,64	2,05	2,35	7,13	8,92	3,23	A+	6,10	5,30	304
		27M 9.000	35M 12.000	2,27	3,03	2,12	5,30	6,41	0,54	1,64	2,05	2,35	7,13	8,92	3,23	A+	6,10	5,30	304
		27M 9.000	53M 18.000	1,77	3,53	2,12	5,30	6,47	0,54	1,64	2,05	2,35	7,13	8,92	3,23	A+	6,10	5,30	304
		35M 12.000	35M 12.000	2,65	2,65	2,12	5,30	6,41	0,54	1,64	2,05	2,35	7,13	8,92	3,23	A+	6,10	5,30	304

Notes Pd = Pdesign CEA = Annual Energy Consumption

MULTISPLIT

HEATING	OUTDOOR UNIT	INDOOR UNIT		HEATING CAPACITY [KW]		TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)				
		A	B	A	B	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.			Class	SCOP	Pd	CEA [kWh]
	MU2-Y 53M (1x1)	20M 8.000	—	2,45	—	1,56	2,50	3,03	0,32	0,67	0,83	1,39	2,90	3,62	3,75	—	—	—	—	
		27M 9.000	—	3,00	—	1,56	3,00	3,63	0,32	0,80	1,00	1,39	3,48	4,35	3,75	—	—	—	—	
		35M 12.000	—	3,80	—	1,56	3,80	4,60	0,32	1,00	1,20	1,39	4,34	5,20	3,81	—	—	—	—	
		53M 18.000	—	5,20	—	1,73	5,20	5,79	0,42	1,35	1,88	1,83	5,87	8,16	3,85	—	—	—	—	
	MU2-Y 53M (1x2)	20M 8.000	20M 8.000	2,50	2,50	2,23	5,00	6,04	0,51	1,35	1,88	2,22	5,86	8,16	3,71	A	4,00	4,30	1505	
		20M 8.000	27M 9.000	2,32	2,98	2,23	5,30	6,13	0,51	1,43	1,88	2,22	6,21	8,16	3,71	A	4,00	4,30	1505	
		20M 8.000	35M 12.000	2,03	3,47	2,23	5,50	6,36	0,51	1,48	1,88	2,22	6,45	8,16	3,71	A	4,00	4,30	1505	
		20M 8.000	53M 18.000	1,60	4,14	2,23	5,70	6,60	0,51	1,54	1,88	2,22	6,68	8,16	3,71	A	4,00	4,30	1505	
		27M 9.000	27M 9.000	2,79	2,79	2,23	5,57	6,68	0,51	1,50	1,88	2,22	6,53	8,16	3,71	A	4,00	4,30	1505	
		27M 9.000	35M 12.000	2,39	3,18	2,23	5,57	6,68	0,51	1,50	1,88	2,22	6,53	8,16	3,71	A	4,00	4,30	1505	
		27M 9.000	53M 18.000	1,86	3,71	2,23	5,57	6,68	0,51	1,50	1,88	2,22	6,53	8,16	3,71	A	4,00	4,30	1505	
		35M 12.000	35M 12.000	2,79	2,79	2,23	5,57	6,68	0,51	1,50	1,88	2,22	6,53	8,16	3,71	A	4,00	4,30	1505	

Notes Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 61M (TRIPLE)

COOLING	OUTDOOR UNIT	INDOOR UNIT		COOLING CAPACITY [KW]			TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14 825)			
				A	B	C	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
		A	B	C	A	B	C	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.				
MU2-Y 61M (1x1)	20M 8.000	—	—	2,30	—	—	1,46	2,00	2,90	0,38	0,62	0,77	1,65	2,69	3,37	3,23	—	—	—	—
	27M 9.000	—	—	2,50	—	—	1,46	2,50	3,20	0,38	0,77	0,97	1,65	3,37	4,21	3,23	—	—	—	—
	35M 12.000	—	—	3,50	—	—	1,46	3,50	3,90	0,38	1,08	1,30	1,65	4,71	5,65	3,23	—	—	—	—
	53M 18.000	—	—	5,00	—	—	1,67	5,00	6,50	0,48	1,55	1,78	2,09	6,73	7,74	3,23	—	—	—	—
	20M 8.000	20M 8.000	—	2,30	2,30	—	2,05	4,20	5,58	0,58	1,30	1,92	2,50	5,65	8,35	3,23	A+	5,60	4,20	263
MU2-Y 61M (1x2)	20M 8.000	27M 9.000	—	2,06	2,64	—	2,05	4,70	5,89	0,58	1,46	2,02	2,50	6,33	8,76	3,23	A+	5,60	4,70	294
	20M 8.000	35M 12.000	—	1,95	3,35	—	2,05	5,30	6,20	0,58	1,64	2,11	2,50	7,13	9,18	3,23	A+	5,60	5,30	331
	20M 8.000	53M 18.000	—	1,76	4,54	—	2,05	6,30	6,94	0,58	1,95	2,21	2,50	8,48	9,60	3,23	A+	5,60	6,10	381
	27M 9.000	27M 9.000	—	2,65	2,65	—	2,05	5,30	6,51	0,58	1,64	2,11	2,50	7,13	9,18	3,23	A+	5,60	5,30	331
	27M 9.000	35M 12.000	—	2,57	3,43	—	2,05	6,00	6,70	0,58	1,86	2,15	2,50	8,08	9,35	3,23	A+	5,60	6,00	375
	27M 9.000	53M 18.000	—	2,10	4,20	—	2,05	6,30	6,94	0,58	1,94	2,21	2,50	8,45	9,60	3,24	A+	5,60	6,10	381
	35M 12.000	35M 12.000	—	3,10	3,10	—	2,05	6,20	6,94	0,58	1,92	2,21	2,50	8,35	9,60	3,23	A+	5,60	6,10	381
	20M 8.000	20M 8.000	20M 8.000	2,30	2,30	2,30	2,48	6,20	7,32	0,69	1,92	2,40	3,00	8,35	10,43	3,23	A++	6,50	6,10	328
	20M 8.000	20M 8.000	27M 9.000	1,89	1,89	2,43	2,48	6,20	7,38	0,69	1,92	2,40	3,00	8,35	10,43	3,23	A++	6,50	6,10	328
	20M 8.000	20M 8.000	35M 12.000	1,67	1,67	2,86	2,48	6,20	7,44	0,69	1,92	2,40	3,00	8,35	10,43	3,23	A++	6,50	6,10	328
MU2-Y 61M (1x3)	20M 8.000	27M 9.000	27M 9.000	1,74	2,23	2,23	2,48	6,20	7,44	0,69	1,92	2,40	3,00	8,35	10,43	3,23	A++	6,50	6,10	328
	20M 8.000	27M 9.000	35M 12.000	1,55	1,99	2,66	2,48	6,20	7,44	0,69	1,92	2,40	3,00	8,35	10,43	3,23	A++	6,50	6,10	328
	27M 9.000	27M 9.000	27M 9.000	2,07	2,07	2,07	2,48	6,20	7,44	0,69	1,92	2,40	3,00	8,35	10,43	3,23	A++	6,50	6,10	328
	27M 9.000	27M 9.000	35M 12.000	1,86	1,86	2,48	2,48	6,20	7,44	0,69	1,92	2,40	3,00	8,35	10,43	3,23	A++	6,50	6,10	328
	27M 9.000	27M 9.000	35M 12.000	1,86	1,86	2,48	2,48	6,20	7,44	0,69	1,92	2,40	3,00	8,35	10,43	3,23	A++	6,50	6,10	328

Notes Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 61M (TRIPLE)

HEATING	OUTDOOR UNIT	INDOOR UNIT			HEATING CAPACITY [KW]			TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	A	B	C	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
	MU2-Y 61M (1x1)	20M 8.000	—	—	2,50	—	—	1,46	2,50	3,03	0,35	0,67	0,84	1,52	2,93	3,66	3,71	—	—	—	—
		27M 9.000	—	—	3,00	—	—	1,46	3,00	3,63	0,35	0,81	1,01	1,52	3,52	4,39	3,71	—	—	—	—
		35M 12.000	—	—	3,80	—	—	1,46	3,80	4,60	0,35	1,02	1,23	1,52	4,45	5,34	3,71	—	—	—	—
		53M 18.000	—	—	5,20	—	—	1,74	5,20	6,63	0,45	1,40	2,00	1,96	6,09	8,68	3,71	—	—	—	—
		20M 8.000	20M 8.000	—	2,50	2,50	—	2,13	5,00	5,80	0,52	1,35	1,74	2,26	5,86	7,55	3,71	A	3,80	4,00	1474
	MU2-Y 61M (1x2)	20M 8.000	27M 9.000	—	2,45	3,15	—	2,13	5,60	6,12	0,52	1,51	1,82	2,26	6,56	7,92	3,71	A	3,80	4,48	1651
		20M 8.000	35M 12.000	—	2,17	3,73	—	2,13	5,90	6,44	0,52	1,59	1,91	2,26	6,91	8,30	3,71	A	3,80	4,80	1768
		20M 8.000	53M 18.000	—	1,82	4,68	—	2,13	6,50	7,21	0,52	1,75	2,00	2,26	7,62	8,68	3,71	A+	3,80	5,12	1886
		27M 9.000	27M 9.000	—	2,95	2,95	—	2,13	5,90	6,76	0,52	1,59	1,91	2,26	6,91	8,30	3,71	A	3,80	4,80	1768
		27M 9.000	35M 12.000	—	2,70	3,60	—	2,13	6,30	6,96	0,52	1,70	1,94	2,26	7,38	8,45	3,71	A+	3,80	5,12	1886
		27M 9.000	53M 18.000	—	2,20	4,40	—	2,13	6,60	7,21	0,52	1,78	2,00	2,26	7,73	8,68	3,71	A+	3,80	5,12	1886
		35M 12.000	35M 12.000	—	3,15	3,15	—	2,13	6,30	7,21	0,52	1,70	2,00	2,26	7,38	8,68	3,71	A+	3,80	5,12	1886
		20M 8.000	20M 8.000	20M 8.000	2,15	2,15	2,15	2,25	6,44	7,60	0,62	1,74	2,17	2,72	7,55	9,43	3,71	A+	4,00	5,40	1890
		20M 8.000	20M 8.000	27M 9.000	1,96	1,96	2,52	2,25	6,44	7,60	0,62	1,74	2,17	2,72	7,55	9,43	3,71	A+	4,00	5,40	1890
		20M 8.000	20M 8.000	35M 12.000	1,73	1,73	2,97	2,25	6,44	7,73	0,62	1,74	2,17	2,72	7,55	9,43	3,71	A+	4,00	5,40	1890
		20M 8.000	27M 9.000	27M 9.000	1,80	2,32	2,32	2,25	6,44	7,73	0,62	1,74	2,17	2,72	7,55	9,43	3,71	A+	4,00	5,40	1890
		20M 8.000	27M 9.000	35M 12.000	1,61	2,07	2,76	2,25	6,44	7,73	0,62	1,74	2,17	2,72	7,55	9,43	3,71	A+	4,00	5,40	1890
	MU2-Y 61M (1x3)	27M 9.000	27M 9.000	27M 9.000	2,15	2,15	2,15	2, 25	6, 44	7,73	0,62	1,74	2,17	2,7 2	7, 55	9, 43	3,71	A+	4,00	5, 04	18 90
		27M 9.000	27M 9.000	35M 12.000	1,93	1,93	2,58	2,25	6,44	7,73	0,62	1,74	2,17	2,72	7,55	9,43	3,71	A+	4,00	5,40	1890

Notes: Pd = Pdesign CEA = Annual Energy Consumption

MULTISPLIT

COMBINATION TABLES

Outdoor unit: MU2-Y 79M (TRIPLE)

	OUTDOOR UNIT	INDOOR UNIT			COOLING CAPACITY [KW]			TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN4825)			
		A	B	C	A	B	C	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
MULTISplit	MU2-Y 79M (1x1)	20M	—	—	2,30	—	—	1,58	2,00	2,90	0,40	0,62	0,77	1,74	2,69	3,37	3,23	—	—	—	—
		8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	—	—	2,50	—	—	1,58	2,50	3,20	0,40	0,77	0,97	1,74	3,37	4,21	3,23	—	—	—	—
		9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	—	—	3,50	—	—	1,58	3,50	3,90	0,40	1,08	1,30	1,74	4,71	5,65	3,23	—	—	—	—
	MU2-Y 79M (1x2)	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		53M	—	—	5,00	—	—	1,78	5,00	6,50	0,50	1,55	1,78	2,17	6,73	7,74	3,23	—	—	—	—
		18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	20M	—	2,10	2,10	—	2,21	4,20	6,32	0,64	1,30	2,08	2,76	5,65	9,04	3,23	A+	5,60	4,20	263
		8.000	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	27M	—	2,36	2,64	—	2,21	4,70	6,72	0,64	1,46	2,20	2,76	6,33	9,57	3,23	A+	5,60	4,70	294
		8.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	35M	—	1,95	3,35	—	2,21	5,30	7,11	0,64	1,64	2,45	2,76	7,13	10,63	3,23	A+	5,60	5,30	331
		8.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	53M	—	1,82	4,68	—	2,21	6,50	7,90	0,64	2,01	2,69	2,76	8,75	11,70	3,23	A+	5,60	6,50	406
		8.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	27M	—	2,65	2,65	—	2,21	5,30	7,11	0,64	1,64	2,45	2,76	7,13	10,63	3,23	A+	5,60	5,30	331
		9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	35M	—	2,57	3,43	—	2,21	6,00	7,51	0,64	1,86	2,57	2,76	8,08	11,17	3,23	A+	5,60	6,00	375
		9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	53M	—	2,27	4,53	—	2,21	6,80	7,90	0,64	2,09	2,69	2,76	9,10	11,70	3,25	A+	5,60	6,80	425
		9.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	35M	—	3,15	3,15	—	2,21	6,30	7,66	0,64	1,94	2,64	2,76	8,45	11,48	3,24	A+	5,60	6,30	394
		12.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	53M	—	2,72	4,08	—	2,21	6,80	7,90	0,64	2,09	2,69	2,76	9,10	11,70	3,25	A+	5,60	6,80	425
		12.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
COOLING	MU2-Y 79M (1x3)	20M	20M	20M	2,30	2,30	2,30	2,77	7,30	8,69	0,76	2,26	2,91	3,30	9,83	12,65	3,23	A++	6,10	7,90	453
		8.000	8.000	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	20M	27M	2,25	2,25	2,90	2,77	7,40	8,69	0,76	2,29	2,91	3,30	9,96	12,65	3,23	A++	6,10	7,90	453
		8.000	8.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	20M	35M	2,13	2,13	3,65	2,77	7,90	8,69	0,76	2,45	2,91	3,30	10,63	12,65	3,23	A++	6,10	7,90	453
		8.000	8.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	20M	53M	1,73	1,73	4,44	2,77	7,90	8,69	0,76	2,45	2,91	3,30	10,63	12,65	3,23	A++	6,10	7,90	453
		8.000	8.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	27M	27M	2,13	2,74	2,74	2,77	7,60	8,69	0,76	2,35	2,91	3,30	10,23	12,65	3,23	A++	6,10	7,90	453
		8.000	9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	27M	35M	1,98	2,54	3,39	2,77	7,90	8,69	0,76	2,45	2,91	3,30	10,63	12,65	3,23	A++	6,10	7,90	453
		8.000	9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	27M	53M	1,63	2,39	4,18	2,77	7,90	8,69	0,76	2,45	2,91	3,30	10,63	12,65	3,23	A++	6,10	7,90	453
		8.000	9.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	35M	35M	1,78	3,06	3,06	2,77	7,90	8,69	0,76	2,45	2,91	3,30	10,63	12,65	3,23	A++	6,10	7,90	453
		8.000	12.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	27M	27M	2,63	2,63	2,63	2,77	7,90	8,69	0,76	2,45	2,91	3,30	10,63	12,65	3,23	A++	6,10	7,90	453
		9.000	9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

Notes Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 79M (TRIPLE)

OUTDOOR UNIT	INDOOR UNIT			HEATING CAPACITY [KW]			TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
	A	B	C	A	B	C	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
MU2-Y 79M (1x1)	20M	—	—	2,50	—	—	1,64	2,50	2,90	0,40	0,67	0,84	1,74	2,91	3,64	3,73	—	—	—	—
	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	27M	—	—	3,00	—	—	1,64	3,00	3,20	0,40	0,80	1,01	1,74	3,50	4,37	3,73	—	—	—	—
	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	35M	—	—	3,80	—	—	1,64	3,80	3,90	0,40	1,02	1,22	1,74	4,43	5,32	3,73	—	—	—	—
	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
MU2-Y 79M (1x2)	53M	—	—	5,20	—	—	1,89	5,20	7,22	0,50	1,39	1,59	2,17	6,03	6,93	3,75	—	—	—	—
	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	20M	—	2,50	2,50	—	2,30	5,00	6,56	0,57	1,34	1,87	2,49	5,83	8,12	3,73	A	3,80	4,80	1768
	8.000	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	27M	—	2,45	3,15	—	2,30	5,60	6,97	0,57	1,50	1,98	2,49	6,53	8,60	3,73	A	3,80	5,00	1842
	8.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	35M	—	2,21	3,79	—	2,30	6,00	7,38	0,57	1,61	2,20	2,49	6,99	9,56	3,73	A	3,80	5,10	1879
	8.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	53M	—	1,96	5,04	—	2,30	7,00	8,20	0,57	1,88	2,42	2,49	8,16	10,51	3,73	A	3,80	5,10	1879
	8.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	27M	27M	—	3,00	3,00	—	2,30	6,00	7,38	0,57	1,61	2,20	2,49	6,99	9,56	3,73	A	3,80	5,10	1879
	9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	27M	35M	—	2,70	3,60	—	2,30	6,30	7,79	0,57	1,69	2,31	2,49	7,34	10,04	3,73	A	3,80	5,10	1879
	9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
MU2-Y 79M (1x3)	27M	53M	—	2,33	4,67	—	2,30	7,00	8,20	0,57	1,88	2,42	2,49	8,16	10,51	3,73	A	3,80	5,10	1879
	9.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	35M	35M	—	3,25	3,25	—	2,30	6,50	7,95	0,57	1,74	2,37	2,49	7,58	10,32	3,73	A	3,80	5,10	1879
	12.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	35M	53M	—	2,80	4,20	—	2,30	7,00	8,20	0,57	1,88	2,42	2,49	8,16	10,51	3,73	A	3,80	5,10	1879
	12.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	20M	20M	2,73	2,73	2,73	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	8.000	8.000	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	20M	27M	2,50	2,50	3,21	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	8.000	8.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	20M	35M	2,21	2,21	3,78	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	8.000	8.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	20M	53M	1,79	1,79	4,61	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	8.000	8.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	27M	27M	2,30	2,95	2,95	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	8.000	9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	27M	35M	2,35	2,64	3,51	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	8.000	9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	20M	27M	53M	1,69	2,17	4,34	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	8.000	9.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
HEATING	20M	35M	35M	1,85	3,17	3,17	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	8.000	12.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	27M	27M	27M	2,73	2,73	2,73	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	9.000	9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	27M	27M	35M	2,46	2,46	3,28	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	9.000	9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
HEATING	27M	35M	35M	2,24	2,98	2,98	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	9.000	12.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	35M	35M	35M	2,73	2,73	2,73	2,87	8,20	9,84	0,68	2,20	2,75	2,96	9,56	11,95	3,73	A+	4,00	5,70	1995
	12.000	12.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

Notes Pd = Pdesign CEA = Annual Energy Consumption

MULTISPLIT

COMBINATION TABLES

Outdoor unit: MU2-Y 82M (QUADRI)

MULTISplit

OUTDOOR UNIT	INDOOR UNIT				COOLING CAPACITY [KW]				TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)			
	A	B	C	D	A	B	C	D	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
MU2-Y 82M (1x1)	20M 8.000	—	—	—	2,30	—	—	—	1,52	2,00	2,90	0,40	0,62	0,77	1,74	2,69	3,37	3,23	—	—	—	—
	27M 9.000	—	—	—	2,50	—	—	—	1,52	2,50	3,20	0,40	0,77	0,97	1,74	3,37	4,21	3,23	—	—	—	—
	35M 12.000	—	—	—	3,50	—	—	—	1,52	3,50	3,90	0,40	1,08	1,30	1,74	4,71	5,65	3,23	—	—	—	—
	53M 18.000	—	—	—	5,00	—	—	—	1,72	5,00	6,50	0,50	1,55	1,78	2,17	6,73	7,74	3,23	—	—	—	—
	20M 8.000	20M 8.000	—	—	2,10	2,10	—	—	2,05	4,20	6,07	0,63	1,30	2,03	2,76	5,65	8,83	3,23	A	5,10	4,20	288
	20M 8.000	27M 9.000	—	—	2,36	2,64	—	—	2,05	4,70	6,40	0,63	1,46	2,16	2,76	6,33	9,38	3,23	A	5,10	4,70	323
MU2-Y 82M (1x2)	20M 8.000	35M 12.000	—	—	1,95	3,35	—	—	2,05	5,30	6,81	0,63	1,64	2,28	2,76	7,13	9,93	3,23	A	5,10	5,30	364
	20M 8.000	53M 18.000	—	—	1,96	5,04	—	—	2,05	7,00	7,54	0,63	2,17	2,79	2,76	9,42	12,14	3,23	A	5,10	7,00	480
	27M 9.000	27M 9.000	—	—	2,65	2,65	—	—	2,05	5,30	6,81	0,63	1,64	2,28	2,76	7,13	9,93	3,23	A	5,10	5,30	364
	27M 9.000	35M 12.000	—	—	2,57	3,43	—	—	2,05	6,00	6,97	0,63	1,86	2,41	2,76	8,08	10,49	3,23	A	5,10	6,00	412
	27M 9.000	53M 18.000	—	—	2,43	4,87	—	—	2,05	7,30	7,54	0,63	2,26	2,79	2,76	9,83	12,14	3,23	A	5,10	7,30	501
	35M 12.000	35M 12.000	—	—	3,25	3,25	—	—	2,05	6,50	7,38	0,63	2,01	2,49	2,76	8,75	10,82	3,23	A	5,10	6,50	446
	35M 12.000	53M 18.000	—	—	2,92	4,38	—	—	2,05	7,30	7,54	0,63	2,26	2,79	2,76	9,83	12,14	3,23	A	5,10	7,30	501
	53M 18.000	53M 18.000	—	—	3,75	3,75	—	—	2,05	7,50	7,54	0,63	2,32	2,79	2,76	10,10	12,14	3,23	A	5,10	7,50	515
	20M 8.000	20M 8.000	20M 8.000	—	2,30	2,30	2,30	—	2,62	6,00	8,45	0,76	1,86	2,94	3,31	8,08	12,80	3,23	A+	6,50	6,00	323
	20M 8.000	20M 8.000	27M 9.000	—	1,98	1,98	2,54	—	2,62	6,50	8,45	0,76	2,01	2,94	3,31	8,75	12,80	3,23	A+	6,50	6,50	350
	20M 8.000	20M 8.000	35M 12.000	—	1,91	1,91	3,28	—	2,62	7,10	8,45	0,76	2,20	2,94	3,31	9,56	12,80	3,23	A+	6,50	7,10	382
	20M 8.000	20M 8.000	53M 18.000	—	1,71	1,71	4,39	—	2,62	7,80	8,45	0,76	2,41	2,94	3,31	10,50	12,80	3,23	A+	6,50	7,80	420
MU2-Y 82M (1x3)	20M 8.000	27M 9.000	27M 9.000	—	1,90	2,45	2,68	—	2,62	6,80	8,45	0,76	2,11	2,94	3,31	9,15	12,80	3,23	A+	6,50	6,80	366
	20M 8.000	27M 9.000	35M 12.000	—	1,88	2,41	3,21	—	2,62	7,50	8,45	0,76	2,32	2,94	3,31	10,10	12,80	3,23	A+	6,50	7,50	404
	20M 8.000	27M 9.000	53M 18.000	—	1,61	2,36	4,13	—	2,62	7,80	8,45	0,76	2,41	2,94	3,31	10,50	12,80	3,23	A+	6,50	7,80	420
	20M 8.000	35M 12.000	35M 12.000	—	1,76	3,02	3,02	—	2,62	7,80	8,45	0,76	2,41	2,94	3,31	10,50	12,80	3,23	A+	6,50	7,80	420
	20M 8.000	35M 12.000	53M 18.000	—	1,48	2,53	3,79	—	2,62	7,80	8,45	0,76	2,41	2,94	3,31	10,50	12,80	3,23	A+	6,50	7,80	420
	27M 9.000	27M 9.000	27M 9.000	—	2,37	2,37	2,37	—	2,62	7,10	8,45	0,76	2,20	2,94	3,31	9,56	12,80	3,23	A+	6,50	7,10	382
	27M 9.000	27M 9.000	35M 12.000	—	2,34	2,34	3,12	—	2,62	7,80	8,45	0,76	2,41	2,94	3,31	10,50	12,80	3,23	A+	6,50	7,80	420
	27M 9.000	27M 9.000	53M 18.000	—	1,95	1,95	3,90	—	2,62	7,80	8,45	0,76	2,41	2,94	3,31	10,50	12,80	3,23	A+	6,50	7,80	420
	27M 9.000	35M 12.000	35M 12.000	—	2,13	2,84	2,84	—	2,62	7,80	8,45	0,76	2,41	2,94	3,31	10,50	12,80	3,23	A+	6,50	7,80	420
	27M 9.000	35M 12.000	53M 18.000	—	1,80	2,40	3,60	—	2,62	7,80	8,45	0,76	2,41	2,94	3,31	10,50	12,80	3,23	A+	6,50	7,80	420
	35M 12.000	35M 12.000	35M 12.000	—	2,60	2,60	2,60	—	2,62	7,80	8,45	0,76	2,41	2,94	3,31	10,50	12,80	3,23	A+	6,50	7,80	420

Notes Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 82M (QUADRI)

COOLING	OUTDOOR UNIT	INDOOR UNIT				COOLING CAPACITY [KW]				TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	D	A	B	C	D	Mi n	Std.	Max.	Mi n	Std.	Max.	Mi n	Std.	Max.		Class	SEER	Pd	CEA [kWh]
MU2-Y 82M (1x4)		20M	20M	20M	20M	2,30	2,30	2,30	2,30	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	8.000	8.000																			
		20M	20M	20M	27M	1,91	1,91	1,91	2,46	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	8.000	8.000	9.000																		
		20M	20M	20M	35M	1,74	1,74	1,74	2,98	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	8.000	8.000	12.000																		
		20M	20M	20M	53M	1,47	1,47	1,47	3,78	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	8.000	8.000	18.000																		
		20M	20M	27M	27M	1,79	1,79	2,31	2,31	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	8.000	9.000	9.000																		
		20M	20M	27M	35M	1,64	1,64	2,11	2,81	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	8.000	9.000	12.000																		
		20M	20M	35M	35M	1,51	1,51	2,59	2,59	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	8.000	8.000	12.000																		
		20M	27M	27M	27M	1,69	2,17	2,17	2,17	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	9.000	9.000	9.000																		
		20M	27M	27M	35M	1,55	1,99	1,99	2,66	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	9.000	9.000	12.000																		
		20M	27M	35M	35M	1,44	1,85	2,46	2,46	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	8.000	8.000	9.000	12.000	12.000																		
		27M	27M	27M	27M	2,35	2,35	2,35	2,35	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	9.000	9.000	9.000	9.000	9.000																		
		27M	27M	27M	35M	1,89	1,89	1,89	2,52	2,87	8,20	9,92	0,86	2,54	3,17	3,75	11,04	13,80	3,23	A++	7,00	8,20	410
	9.000	9.000	9.000	9.000	12.000																		

Notes Pd = Pdesign CEA = Annual Energy Consumption

MULTISPLIT

COMBINATION TABLES

Outdoor unit: MU2-Y 82M (QUADRI)

MULTISplit

OUTDOOR UNIT	INDOOR UNIT				HEATING CAPACITY [KW]				TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
	A	B	C	D	A	B	C	D	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
MU2-Y 82M (fx1)	20M 8.000	—	—	—	2,50	—	—	—	1,63	2,50	2,90	0,40	0,67	0,83	1,74	2,90	3,62	3,75	—	—	—	—
	27M 9.000	—	—	—	3,00	—	—	—	1,63	3,00	3,20	0,40	0,80	1,00	1,74	3,48	4,35	3,75	—	—	—	—
	35M 12.000	—	—	—	3,80	—	—	—	1,63	3,80	3,90	0,40	1,01	1,22	1,74	4,41	5,29	3,75	—	—	—	—
	53M 18.000	—	—	—	5,60	—	—	—	1,85	5,60	6,78	0,50	1,48	1,70	2,17	6,44	7,41	3,78	—	—	—	—
	20M 8.000	20M 8.000	—	—	2,50	2,50	—	—	2,20	5,00	6,51	0,59	1,31	1,90	2,58	5,71	8,25	3,81	A	3,40	3,85	1585
	20M 8.000	27M 9.000	—	—	2,45	3,15	—	—	2,20	5,60	6,86	0,59	1,47	2,02	2,58	6,39	8,77	3,81	A	3,40	4,31	1776
MU2-Y 82M (fx2)	20M 8.000	35M 12.000	—	—	2,21	3,79	—	—	2,20	6,00	7,30	0,59	1,57	2,13	2,58	6,85	9,28	3,81	A	3,40	4,62	1902
	20M 8.000	53M 18.000	—	—	2,18	5,62	—	—	2,20	7,80	8,10	0,59	2,03	2,61	2,58	8,81	11,34	3,85	A	3,40	6,01	2473
	27M 9.000	27M 9.000	—	—	3,00	3,00	—	—	2,20	6,00	7,30	0,59	1,57	2,13	2,58	6,85	9,28	3,81	A	3,40	4,62	1902
	27M 9.000	35M 12.000	—	—	3,00	4,00	—	—	2,20	7,00	7,48	0,59	1,84	2,25	2,58	7,99	9,80	3,81	A	3,40	5,39	2219
	27M 9.000	53M 18.000	—	—	2,63	5,27	—	—	2,20	7,90	8,10	0,59	2,05	2,61	2,58	8,92	11,34	3,85	A	3,40	6,08	2505
	35M 12.000	35M 12.000	—	—	3,75	3,75	—	—	2,20	7,50	7,92	0,59	1,97	2,32	2,58	8,56	10,11	3,81	A	3,40	5,78	2378
	35M 12.000	53M 18.000	—	—	3,20	4,80	—	—	2,20	8,00	8,10	0,59	2,08	2,61	2,58	9,03	11,34	3,85	A	3,40	6,08	2505
	53M 18.000	53M 18.000	—	—	4,00	4,00	—	—	2,20	8,00	8,10	0,59	2,08	2,61	2,58	9,03	11,34	3,85	A	3,40	6,08	2505
	20M 8.000	20M 8.000	20M 8.000	—	2,33	2,33	2,33	—	2,82	7,00	9,06	0,71	1,89	2,75	3,09	8,20	11,96	3,71	A	3,50	5,39	2156
	20M 8.000	20M 8.000	27M 9.000	—	2,37	2,37	3,05	—	2,82	7,80	9,06	0,71	2,10	2,75	3,09	9,14	11,96	3,71	A	3,50	6,01	2402
	20M 8.000	20M 8.000	35M 12.000	—	2,26	2,26	3,88	—	2,82	8,40	9,06	0,71	2,26	2,75	3,09	9,84	11,96	3,71	A	3,50	6,10	2440
	20M 8.000	20M 8.000	53M 18.000	—	1,88	1,88	4,84	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480
	20M 8.000	27M 9.000	27M 9.000	—	2,35	3,02	2,68	—	2,82	8,40	9,06	0,71	2,26	2,75	3,09	9,84	11,96	3,71	A	3,50	6,10	2440
	20M 8.000	27M 9.000	35M 12.000	—	2,13	2,73	3,64	—	2,82	8,50	9,06	0,71	2,29	2,75	3,09	9,96	11,96	3,71	A	3,50	6,20	2480
20M 8.000	27M 9.000	53M 18.000	—	1,77	2,28	4,55	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480	
MU2-Y 82M (fx3)	20M 8.000	35M 12.000	—	—	1,94	3,33	3,33	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480
	20M 8.000	35M 12.000	—	—	1,63	2,79	4,18	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480
	20M 8.000	12.000	18.000	—	2,87	2,87	2,87	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480
	27M 9.000	27M 9.000	35M 12.000	—	2,58	2,58	3,44	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480
	27M 9.000	27M 9.000	53M 18.000	—	2,15	2,15	4,30	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480
	27M 9.000	35M 12.000	35M 12.000	—	2,35	3,13	3,13	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480
	27M 9.000	35M 12.000	53M 18.000	—	1,98	2,65	3,97	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480
	35M 12.000	35M 12.000	35M 12.000	—	2,87	2,87	2,87	—	2,82	8,60	9,06	0,71	2,32	2,75	3,09	10,08	11,96	3,71	A	3,50	6,20	2480

HEATING

Notes Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 82M (QUADRI)

HEATING	OUTDOOR UNIT	INDOOR UNIT				HEATING CAPACITY [KW]				TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	D	A	B	C	D	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
	MU2-Y 82M (1x4)	20M 8.000	20M 8.000	20M 8.000	20M 8.000	2,20	2,20	2,20	2,20	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275
		20M 8.000	20M 8.000	20M 8.000	27M 9.000	2,35	2,35	2,35	2,64	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275
		20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,87	1,87	1,87	3,20	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275
		20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,58	1,58	1,58	4,06	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275
		20M 8.000	20M 8.000	27M 9.000	27M 9.000	1,93	1,93	2,48	2,48	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275
		20M 8.000	20M 8.000	27M 9.000	35M 12.000	1,76	1,76	2,26	3,02	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275
		20M 8.000	20M 8.000	35M 12.000	35M 12.000	1,62	1,62	2,78	2,78	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275
		20M 8.000	27M 9.000	27M 9.000	27M 9.000	1,81	2,33	2,33	2,33	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275
20M 8.000		27M 9.000	27M 9.000	35M 12.000	1,66	2,14	2,14	2,85	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275	
20M 8.000		27M 9.000	35M 12.000	35M 12.000	1,54	1,98	2,64	2,64	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275	
27M 9.000	27M 9.000	27M 9.000	27M 9.000	2,20	2,20	2,20	2,20	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275		
27M 9.000	27M 9.000	27M 9.000	35M 12.000	2,33	2,33	2,33	2,71	3,08	8,80	10,65	0,81	2,37	2,96	3,51	10,31	12,89	3,71	A	4,00	6,50	2275		

Notes Pd = Pdesign CEA = Annual Energy Consumption

MULTISPLIT

COMBINATION TABLES

Outdoor unit: MU2-Y 105M (QUADRI)

COOLING	OUTDOOR UNIT	INDOOR UNIT				COOLING CAPACITY [KW]				TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	D	A	B	C	D	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
MU2-Y 105M (1x4)	20M	—	—	—	—	2,00	—	—	—	1,58	2,00	2,90	0,45	0,61	0,76	1,96	2,85	3,56	3,28	—	—	—	—
	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	27M	—	—	—	—	2,50	—	—	—	1,58	2,50	3,20	0,45	0,76	0,95	1,96	3,56	4,45	3,28	—	—	—	—
	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	35M	—	—	—	—	3,50	—	—	—	1,58	3,50	3,90	0,45	1,07	1,28	1,96	4,99	5,99	3,28	—	—	—	—
	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	53M	—	—	—	—	5,00	—	—	—	1,79	5,00	6,50	0,58	1,52	1,75	2,52	7,13	8,20	3,28	—	—	—	—
	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	70M	—	—	—	—	7,00	—	—	—	2,21	7,00	8,00	0,62	2,13	2,45	2,70	9,98	11,48	3,28	—	—	—	—
	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	HYDRO-M	—	—	—	—	10,60	—	—	—	-	10,60	-	-	3,50	-	-	-	-	3,01	A++	6,10	10,60	613
MU2-Y 105M (1x2)	20M	20M	—	—	—	2,10	2,10	—	—	2,21	4,20	6,30	0,62	1,28	2,11	2,89	5,99	9,89	3,28	A++	6,10	4,20	241
	8.000	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	20M	27M	—	—	—	2,06	2,64	—	—	2,21	4,70	6,51	0,62	1,43	2,28	2,89	6,70	10,65	3,28	A++	6,10	4,70	270
	8.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	20M	35M	—	—	—	2,03	3,47	—	—	2,21	5,50	6,83	0,62	1,68	2,44	2,89	7,84	11,41	3,28	A++	6,10	5,50	316
	8.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	20M	53M	—	—	—	1,96	5,04	—	—	2,21	7,00	8,40	0,62	2,13	2,86	2,89	9,98	13,39	3,28	A++	6,10	7,00	402
	8.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	20M	70M	—	—	—	2,03	6,97	—	—	2,21	9,00	9,45	0,62	2,74	3,06	2,89	12,83	14,30	3,28	A++	6,10	9,00	516
	8.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	27M	27M	—	—	—	2,65	2,65	—	—	2,21	5,30	6,83	0,62	1,62	2,44	2,89	7,56	11,41	3,28	A++	6,10	5,30	304
	9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	27M	35M	—	—	—	2,57	3,43	—	—	2,21	6,00	7,35	0,62	1,83	2,60	2,89	8,55	12,17	3,28	A++	6,10	6,00	344
	9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	27M	53M	—	—	—	2,50	5,00	—	—	2,21	7,50	9,45	0,62	2,29	2,93	2,89	10,69	13,70	3,28	A++	6,10	7,50	430
	9.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
	27M	70M	—	—	—	2,59	6,91	—	—	2,21	9,50	9,98	0,62	2,90	3,12	2,89	13,54	14,61	3,28	A++	6,10	9,50	545
	9.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
35M	35M	—	—	—	3,50	3,50	—	—	2,21	7,00	7,88	0,62	2,13	2,76	2,89	9,98	12,93	3,28	A++	6,10	7,00	402	
12.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—		
35M	53M	—	—	—	3,40	5,10	—	—	2,21	8,50	9,98	0,62	2,59	2,93	2,89	12,12	13,70	3,28	A++	6,10	8,50	488	
12.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—		
35M	70M	—	—	—	3,33	6,67	—	—	2,21	10,00	10,50	0,62	3,09	3,19	2,89	14,44	14,91	3,24	A++	6,10	10,00	574	
12.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—		
53M	53M	—	—	—	5,00	5,00	—	—	2,21	10,00	10,50	0,62	3,09	3,25	2,89	14,44	15,22	3,24	A++	6,10	10,00	574	
18.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—		

Notes Pd = Pdesign CEA = Annual Energy Consumption

replaceable indoor unit with HYDRO-M hydronic module

Note: Hydraulic module and direct expansion indoor units cannot operate at the same time.

COMBINATION TABLES

Outdoor unit: MU2-Y 105M (QUADRI)

OUTDOOR UNIT	INDOOR UNIT				COOLING CAPACITY [KW]				TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)			
	A	B	C	D	A	B	C	D	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
MU2-Y 105M (hx3)	20M	20M	20M	—	2,00	2,00	2,00	—	2,84	6,00	7,35	0,78	1,80	2,93	3,65	8,42	13,70	3,33	A++	6,30	6,00	333
	8.000	8.000	8.000	—	1,98	1,98	2,54	—	2,84	6,50	7,88	0,78	1,98	3,09	3,65	9,27	14,46	3,28	A++	6,30	6,50	361
	20M	20M	27M	—	2,02	2,02	3,46	—	2,84	7,50	8,93	0,78	2,29	3,25	3,65	10,69	15,22	3,28	A++	6,30	7,50	417
	8.000	8.000	9.000	—	1,97	1,97	5,06	—	2,84	9,00	11,55	0,78	2,74	3,58	3,65	12,83	16,74	3,28	A++	6,30	9,00	500
	20M	20M	53M	—	1,84	1,84	6,32	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	8.000	8.000	18.000	—	1,96	2,52	2,52	—	2,84	7,00	8,93	0,78	2,13	3,25	3,65	9,98	15,22	3,28	A++	6,30	7,00	389
	20M	27M	27M	—	2,00	2,57	3,43	—	2,84	8,00	9,98	0,78	2,44	3,41	3,65	11,40	15,98	3,28	A++	6,30	8,00	444
	8.000	9.000	9.000	—	1,96	2,51	5,03	—	2,84	9,50	11,55	0,78	2,93	3,58	3,65	13,72	16,74	3,24	A++	6,30	9,50	528
	20M	27M	53M	—	1,75	2,25	6,00	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	8.000	9.000	24.000	—	2,03	3,48	3,48	—	2,84	9,00	10,50	0,78	2,78	3,41	3,65	13,00	15,98	3,24	A++	6,30	9,00	500
	20M	35M	35M	—	1,89	3,24	4,86	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	8.000	12.000	12.000	—	1,63	2,79	5,58	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	20M	35M	70M	—	1,63	4,19	4,19	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	8.000	12.000	24.000	—	2,50	2,50	2,50	—	2,84	7,50	9,98	0,78	2,31	3,41	3,65	10,83	15,98	3,24	A++	6,30	7,50	417
	20M	53M	53M	—	2,55	2,55	3,40	—	2,84	8,50	10,50	0,78	2,62	3,41	3,65	12,28	15,98	3,24	A++	6,30	8,50	472
	8.000	18.000	18.000	—	2,50	2,50	5,00	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	20M	27M	70M	—	2,14	2,14	5,71	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	8.000	9.000	24.000	—	2,59	3,45	3,45	—	2,84	9,50	11,55	0,78	2,93	3,58	3,65	13,72	16,74	3,24	A++	6,30	9,50	528
	20M	35M	35M	—	2,31	3,08	4,62	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	8.000	12.000	18.000	—	2,00	2,67	5,33	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	20M	35M	70M	—	2,00	4,00	4,00	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	8.000	9.000	24.000	—	3,33	3,33	3,33	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	20M	35M	53M	—	2,86	2,86	4,29	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	8.000	12.000	18.000	—	2,50	2,50	5,00	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	20M	35M	70M	—	2,50	3,75	3,75	—	2,84	10,00	11,55	0,78	3,09	3,58	3,65	14,44	16,74	3,24	A++	6,30	10,00	556
	8.000	12.000	24.000	—																		
	20M	53M	53M	—																		
	8.000	18.000	18.000	—																		
	35M	35M	35M	—																		
	12.000	12.000	12.000	—																		
	35M	35M	53M	—																		
	12.000	12.000	18.000	—																		
	35M	35M	70M	—																		
	12.000	12.000	24.000	—																		
	35M	53M	53M	—																		
	12.000	18.000	18.000	—																		

Notes Pd = Pdesign CEA = Annual Energy Consumption

replaceable indoor unit with HYDRO-M hydronic module

Note: Hydraulic module and direct expansion indoor units cannot operate at the same time.

MULTISPLIT

COMBINATION TABLES

Outdoor unit: MU2-Y 105M (QUADRI)

COOLING	OUTDOOR UNIT	INDOOR UNIT				COOLING CAPACITY [KW]				TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14 825)			CEA [kWh]
		A	B	C	D	A	B	C	D	Min	Std.	Max.	Min.	Std.	Max.	Min	Std.	Max.		Class	SEER	Pd	
MU2-Y 105M (1x4)		20M	20M	20M	20M	2,05	2,05	2,05	2,05	3,68	8,20	10,50	0,88	2,29	3,25	4,11	10,64	15,22	3,58	A++	6,50	8,20	442
		8.000	8.000	8.000	8.000																		
		20M	20M	20M	27M	1,98	1,98	1,98	2,55	3,68	8,50	11,55	0,88	2,47	3,41	4,11	11,51	15,98	3,44	A++	6,50	8,50	458
		8.000	8.000	8.000	9.000																		
		20M	20M	20M	35M	2,02	2,02	2,02	3,45	3,68	9,50	12,60	0,88	2,86	3,84	4,11	13,37	17,96	3,32	A++	6,50	9,50	512
		8.000	8.000	8.000	12.000																		
		20M	20M	20M	53M	1,87	1,87	1,87	4,80	3,68	10,40	13,65	0,88	3,22	3,97	4,11	15,07	18,57	3,23	A++	6,50	10,40	560
		8.000	8.000	8.000	18.000																		
		20M	20M	20M	70M	1,63	1,63	1,63	5,60	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	8.000	8.000	24.000																		
		20M	20M	27M	27M	1,97	1,97	2,53	2,53	3,68	9,00	12,60	0,88	2,71	3,84	4,11	12,66	17,96	3,32	A++	6,50	9,00	485
		8.000	8.000	9.000	9.000																		
		20M	20M	27M	35M	2,00	2,00	2,57	3,43	3,68	10,00	13,13	0,88	3,09	3,90	4,11	14,44	18,26	3,24	A++	6,50	10,00	538
		8.000	8.000	9.000	12.000																		
		20M	20M	27M	53M	1,79	1,79	2,30	4,61	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	8.000	9.000	18.000																		
		20M	20M	27M	70M	1,56	1,56	2,01	5,36	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	8.000	9.000	24.000																		
		20M	20M	35M	35M	1,93	1,93	3,32	3,32	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	8.000	12.000	12.000																		
		20M	20M	35M	53M	1,67	1,67	2,86	4,30	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	8.000	12.000	18.000																		
		20M	20M	53M	53M	1,47	1,47	3,78	3,78	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	8.000	18.000	18.000																		
		20M	27M	27M	27M	1,96	2,51	2,51	2,51	3,68	9,50	13,13	0,88	2,92	3,84	4,11	13,68	17,96	3,25	A++	6,50	9,50	512
		8.000	9.000	9.000	9.000																		
		20M	27M	27M	35M	1,99	2,55	2,55	3,41	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	9.000	9.000	12.000																		
		20M	27M	27M	53M	1,71	2,20	2,20	4,40	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	9.000	9.000	18.000																		
		20M	27M	27M	70M	1,50	1,93	1,93	5,14	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	9.000	9.000	24.000																		
		20M	27M	35M	35M	1,84	2,36	3,15	3,15	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	9.000	12.000	12.000																		
		20M	27M	35M	53M	1,60	2,05	2,74	4,11	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	9.000	12.000	18.000																		
		20M	27M	53M	53M	1,41	1,82	3,63	3,63	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	9.000	18.000	18.000																		
		20M	35M	35M	35M	1,71	2,93	2,93	2,93	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	12.000	12.000	12.000																		
		20M	35M	35M	53M	1,50	2,57	2,57	3,86	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		8.000	12.000	12.000	18.000																		
		27M	27M	27M	27M	2,63	2,63	2,63	2,63	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		9.000	9.000	9.000	9.000																		
		27M	27M	27M	35M	2,22	2,42	2,42	3,23	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		9.000	9.000	9.000	12.000																		
		27M	27M	27M	53M	2,10	2,10	2,00	14,20	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		9.000	9.000	9.000	18.000																		
		27M	27M	35M	35M	2,25	2,25	3,00	3,00	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		9.000	9.000	12.000	12.000																		
		27M	27M	35M	53M	1,97	1,97	2,63	3,94	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		9.000	9.000	12.000	18.000																		
		27M	35M	35M	35M	2,10	2,80	2,80	2,80	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		9.000	12.000	12.000	12.000																		
		27M	35M	35M	53M	1,85	2,47	2,47	3,71	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		9.000	12.000	12.000	18.000																		
		35M	35M	35M	35M	2,63	2,63	2,63	2,63	3,68	10,50	13,65	0,88	3,25	3,97	4,11	15,22	18,57	3,23	A++	6,50	10,50	565
		12.000	12.000	12.000	12.000																		

Notes Pd = Pdesign CEA = Annual Energy Consumption

replaceable indoor unit with HYDRO-M hydronic module

Note: Hydraulic module and direct expansion indoor units cannot operate at the same time.

COMBINATION TABLES

Outdoor unit: MU2-Y 105M (QUADRI)

	OUTDOOR UNIT	INDOOR UNIT				HEATING CAPACITY [KW]				TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	D	A	B	C	D	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
HEATING	MU2-Y 105M (1x1)	20M	—	—	—	2,50	—	—	—	1,67	2,50	2,90	0,45	0,67	0,84	1,96	3,00	3,75	3,71	—	—	—	—
		8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	—	—	—	3,00	—	—	—	1,67	3,00	3,20	0,45	0,81	1,01	1,96	3,60	4,50	3,71	—	—	—	—
		9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	—	—	—	3,80	—	—	—	1,67	3,80	3,90	0,45	1,02	1,23	1,96	4,56	5,48	3,71	—	—	—	—
		12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		53M	—	—	—	5,20	—	—	—	1,89	5,20	7,00	0,55	1,40	1,61	2,39	6,74	7,76	3,71	—	—	—	—
		18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		70M	—	—	—	7,20	—	—	—	1,89	7,20	8,00	0,58	1,94	2,23	2,52	8,79	10,11	3,71	—	—	—	—
		24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		HYDRO-M	—	—	—	11,10	—	—	—	—	11,10	—	—	3,00	—	—	—	—	3,71	A	3,80	8,80	3246
	MU2-Y 105M (1x2)	20M	20M	—	—	2,50	2,50	—	—	2,33	5,00	6,66	0,57	1,35	1,94	2,51	5,99	8,57	3,71	A	3,50	4,34	1736
		8.000	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	27M	—	—	2,45	3,15	—	—	2,33	5,60	6,88	0,57	1,51	2,09	2,51	6,71	9,23	3,71	A	3,50	3,88	1550
		8.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	35M	—	—	2,21	3,79	—	—	2,33	6,00	7,22	0,57	1,62	2,24	2,51	7,19	9,89	3,71	A	3,50	4,34	1736
		8.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	53M	—	—	2,24	5,76	—	—	2,33	8,00	8,88	0,57	2,16	2,63	2,51	9,61	11,60	3,71	A	3,40	4,65	1915
		8.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	70M	—	—	2,17	7,43	—	—	2,33	9,60	10,77	0,57	2,59	2,81	2,51	11,53	12,39	3,71	A	3,40	4,65	1915
		8.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	27M	—	—	3,00	3,00	—	—	2,33	6,00	7,22	0,57	1,62	2,24	2,51	7,19	9,89	3,71	A	3,50	6,20	2480
		9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	35M	—	—	3,00	4,00	—	—	2,33	7,00	7,77	0,57	1,89	2,39	2,51	8,38	10,55	3,71	A	3,50	4,65	1860
		9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	53M	—	—	2,93	5,87	—	—	2,33	8,80	9,99	0,57	2,37	2,69	2,51	10,57	11,87	3,71	A	3,40	5,43	2234
		9.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	70M	—	—	2,67	7,13	—	—	2,33	9,80	10,66	0,57	2,64	2,84	2,51	11,77	12,53	3,71	A	3,40	4,65	1915
		9.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	35M	—	—	3,75	3,75	—	—	2,33	7,50	8,33	0,57	2,02	2,54	2,51	9,01	11,21	3,71	A	3,50	6,82	2728
		12.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	53M	—	—	3,76	5,64	—	—	2,33	9,40	10,55	0,57	2,53	2,69	2,51	11,29	11,87	3,71	A	3,40	5,81	2393
		12.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	70M	—	—	3,33	6,67	—	—	2,33	10,00	10,88	0,57	2,70	2,93	2,51	12,01	12,92	3,71	A	3,40	4,65	1915
		12.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		53M	53M	—	—	5,05	5,05	—	—	2,33	10,10	11,10	0,57	2,72	2,99	2,51	12,16	13,19	3,71	A	3,60	7,29	2833
		18.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

Notes Pd = Pdesign CEA = Annual Energy Consumption

replaceable indoor unit with HYDRO-M hydronic module

Note: Hydraulic module and direct expansion indoor units cannot operate at the same time.

MULTISPLIT

COMBINATION TABLES

Outdoor unit: MU2-Y 105M (QUADRI)

HEATING	OUTDOOR UNIT	INDOOR UNIT				HEATING CAPACITY [KW]				TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY [EN14825]			
						A	B	C	D	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
		A	B	C	D	A	B	C	D	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.					
MU2-Y 105M (1x3)	20M	20M	20M	—	2,50	2,50	2,50	—	3,00	7,50	7,77	0,72	2,02	2,69	3,16	8,93	11,87	3,71	A	3,60	8,53	3315	
	8.000	8.000	8.000	—	2,37	2,37	3,05	—	3,00	7,80	8,33	0,72	2,10	2,84	3,16	9,29	12,53	3,71	A	3,60	5,81	2260	
	20M	20M	27M	—	2,29	2,29	3,92	—	3,00	8,50	9,44	0,72	2,29	2,99	3,16	10,13	13,19	3,71	A	3,60	6,05	2351	
	8.000	8.000	9.000	—	2,29	2,29	3,92	—	3,00	8,50	9,44	0,72	2,29	2,99	3,16	10,13	13,19	3,71	A	3,60	6,05	2351	
	20M	20M	35M	—	2,34	2,34	6,02	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	6,59	2562	
	8.000	8.000	12.000	—	2,34	2,34	6,02	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	6,59	2562	
	20M	20M	70M	—	1,97	1,97	6,76	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	6,59	2562	
	8.000	8.000	24.000	—	1,97	1,97	6,76	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	6,59	2562	
	20M	27M	27M	—	2,38	3,06	3,06	—	3,00	8,50	9,44	0,72	2,29	2,99	3,16	10,13	13,19	3,71	A	3,60	8,91	3466	
	8.000	9.000	9.000	—	2,38	3,06	3,06	—	3,00	8,50	9,44	0,72	2,29	2,99	3,16	10,13	13,19	3,71	A	3,60	8,91	3466	
	20M	27M	35M	—	2,50	3,21	4,29	—	3,00	10,00	10,55	0,72	2,70	3,14	3,16	11,91	13,85	3,71	A	3,60	6,59	2562	
	8.000	9.000	12.000	—	2,50	3,21	4,29	—	3,00	10,00	10,55	0,72	2,70	3,14	3,16	11,91	13,85	3,71	A	3,60	6,59	2562	
	20M	27M	53M	—	2,20	2,83	5,66	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	7,75	3014	
	8.000	9.000	18.000	—	2,20	2,83	5,66	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	7,75	3014	
	20M	27M	70M	—	1,87	2,41	6,42	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	7,75	3014	
	8.000	9.000	24.000	—	1,87	2,41	6,42	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	7,75	3014	
	20M	35M	35M	—	2,28	3,91	3,91	—	3,00	10,10	11,10	0,72	2,72	3,14	3,16	12,10	13,85	3,71	A	3,60	8,91	3466	
	8.000	12.000	12.000	—	2,28	3,91	3,91	—	3,00	10,10	11,10	0,72	2,72	3,14	3,16	12,10	13,85	3,71	A	3,60	8,91	3466	
	20M	35M	53M	—	2,02	3,47	5,21	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,53	3315	
	8.000	12.000	18.000	—	2,02	3,47	5,21	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,53	3315	
	20M	35M	70M	—	1,74	2,99	5,97	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,53	3315	
	8.000	12.000	24.000	—	1,74	2,99	5,97	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,53	3315	
	20M	53M	53M	—	1,74	4,48	4,48	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,89	14,50	3,71	A	3,60	8,91	3466	
	8.000	18.000	18.000	—	1,74	4,48	4,48	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,89	14,50	3,71	A	3,60	8,91	3466	
	27M	27M	27M	—	3,33	3,33	3,33	—	3,00	10,00	10,55	0,72	2,70	3,14	3,16	11,98	13,85	3,71	A	3,60	8,91	3466	
	9.000	9.000	9.000	—	3,33	3,33	3,33	—	3,00	10,00	10,55	0,72	2,70	3,14	3,16	11,98	13,85	3,71	A	3,60	8,91	3466	
	27M	27M	35M	—	3,03	3,03	4,04	—	3,00	10,10	11,10	0,72	2,72	3,14	3,16	12,10	13,85	3,71	A	3,60	7,75	3014	
	9.000	9.000	12.000	—	3,03	3,03	4,04	—	3,00	10,10	11,10	0,72	2,72	3,14	3,16	12,10	13,85	3,71	A	3,60	7,75	3014	
27M	27M	53M	—	2,68	2,68	5,35	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,89	14,50	3,71	A	3,60	8,53	3315		
9.000	9.000	18.000	—	2,68	2,68	5,35	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,89	14,50	3,71	A	3,60	8,53	3315		
27M	27M	70M	—	2,29	2,29	6,11	—	2,73	10,70	11,11	0,63	2,88	2,90	2,79	12,85	12,78	3,71	A	3,60	8,53	3315		
9.000	9.000	24.000	—	2,29	2,29	6,11	—	2,73	10,70	11,11	0,63	2,88	2,90	2,79	12,85	12,78	3,71	A	3,60	8,53	3315		
27M	35M	35M	—	2,92	3,89	3,89	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	8,91	3466		
9.000	12.000	12.000	—	2,92	3,89	3,89	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	8,91	3466		
27M	35M	53M	—	2,47	3,29	4,94	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		
9.000	12.000	18.000	—	2,47	3,29	4,94	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		
27M	35M	70M	—	2,14	2,85	5,71	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		
9.000	12.000	24.000	—	2,14	2,85	5,71	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		
27M	53M	53M	—	2,14	4,28	4,28	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,89	14,50	3,71	A	3,60	8,91	3466		
9.000	18.000	18.000	—	2,14	4,28	4,28	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,89	14,50	3,71	A	3,60	8,91	3466		
35M	35M	35M	—	3,57	3,57	3,57	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	8,91	3466		
12.000	12.000	12.000	—	3,57	3,57	3,57	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,82	14,50	3,71	A	3,60	8,91	3466		
35M	35M	53M	—	3,06	3,06	4,59	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		
12.000	12.000	18.000	—	3,06	3,06	4,59	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		
35M	35M	70M	—	2,68	2,68	5,35	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		
12.000	12.000	24.000	—	2,68	2,68	5,35	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		
35M	53M	53M	—	2,68	4,01	4,01	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		
12.000	18.000	18.000	—	2,68	4,01	4,01	—	3,00	10,70	12,21	0,72	2,88	3,29	3,16	12,85	14,50	3,71	A	3,60	8,91	3466		

Notes Pd = Pdesign CEA = Annual Energy Consumption

replaceable indoor unit with HYDRO-M hydronic module

Note: Hydraulic module and direct expansion indoor units cannot operate at the same time.

COMBINATION TABLES

Outdoor unit: MU2-Y 105M (QUADRI)

OUTDOOR UNIT	INDOOR UNIT				HEATING CAPACITY [KW]				TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
	A	B	C	D	A	B	C	D	Mi n.	Std.	Max.	Mi n.	Std.	Max.	Mi n.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
	20M	20M	20M	20M	2,50	2,50	2,50	2,50	3,89	10,00	11,10	0,81	2,56	2,99	3,56	11,26	13,19	3,91	A+	4,00	8,91	3119
MU2-Y 105M (1x4)	8.000	8.000	8.000	8.000	2,36	2,36	2,36	3,03	3,89	10,10	11,66	0,81	2,64	3,14	3,56	11,62	13,85	3,83	A+	4,00	7,75	2713
	20M	20M	20M	27M	2,31	2,31	2,31	3,96	3,89	10,90	12,21	0,81	2,90	3,29	3,56	12,77	14,50	3,76	A+	4,00	8,53	2984
	8.000	8.000	8.000	12.000	1,99	1,99	1,99	5,12	3,89	11,10	13,32	0,81	2,98	3,89	3,56	13,11	17,14	3,73	A+	4,00	9,15	3201
	20M	20M	20M	35M	1,73	1,73	1,73	5,92	3,89	11,10	13,32	0,81	2,98	3,89	3,56	13,11	17,14	3,73	A+	4,00	9,15	3201
	8.000	8.000	8.000	18.000	2,38	2,38	3,07	3,07	3,89	10,90	12,21	0,81	2,90	3,29	3,56	12,77	14,50	3,76	A+	4,00	9,20	3220
	20M	20M	27M	9.000	2,22	2,22	2,85	3,81	3,89	11,10	12,77	0,81	2,95	3,59	3,56	13,01	15,82	3,76	A+	4,00	9,15	3201
	8.000	8.000	9.000	12.000	1,90	1,90	2,44	4,87	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	20M	20M	27M	18.000	1,65	1,65	2,13	5,67	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	8.000	8.000	9.000	24.000	2,04	2,04	3,51	3,51	3,89	11,10	13,32	0,81	2,98	3,89	3,56	13,11	17,14	3,73	A+	4,00	9,20	3220
	20M	20M	35M	35M	1,77	1,77	3,03	4,54	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,22	17,14	3,71	A+	4,00	9,20	3220
	8.000	8.000	12.000	18.000	1,55	1,55	4,00	4,00	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,22	17,14	3,71	A+	4,00	9,20	3220
	20M	20M	53M	53M	2,29	2,94	2,94	2,94	3,89	11,10	12,77	0,81	2,95	3,44	3,56	13,01	15,16	3,76	A+	4,00	9,20	3220
	8.000	8.000	9.000	9.000	2,10	2,70	2,70	3,60	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,22	17,14	3,71	A+	4,00	9,20	3220
	20M	27M	27M	12.000	1,81	2,32	2,32	4,65	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	8.000	9.000	9.000	18.000	1,59	2,04	2,04	5,44	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	20M	27M	27M	24.000	1,94	2,50	3,33	3,33	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,22	17,14	3,71	A+	4,00	9,20	3220
	8.000	9.000	12.000	12.000	1,69	2,17	2,90	4,34	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	20M	27M	35M	53M	1,49	1,92	3,84	3,84	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	8.000	9.000	18.000	18.000	1,81	3,10	3,10	3,10	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	20M	35M	35M	35M	1,59	2,72	2,72	4,08	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	8.000	12.000	12.000	18.000	2,78	2,78	2,78	2,77	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	27M	27M	27M	9.000	2,56	2,56	2,56	3,42	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	9.000	9.000	9.000	12.000	2,22	2,22	2,22	4,44	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	27M	27M	27M	18.000	2,38	2,38	3,17	3,17	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	9.000	9.000	12.000	12.000	2,08	2,08	2,78	4,16	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	27M	27M	35M	35M	2,22	2,96	2,96	2,96	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	9.000	12.000	12.000	12.000	1,96	2,61	2,61	3,92	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	27M	35M	35M	53M	2,78	2,78	2,78	2,77	3,89	11,10	13,32	0,81	2,99	3,89	3,56	13,19	17,14	3,71	A+	4,00	9,20	3220
	9.000	12.000	12.000	18.000																		
	35M	35M	35M	35M																		
	12.000	12.000	12.000	12.000																		

Notes Pd = Pdesign CEA = Annual Energy Consumption

replaceable indoor unit with HYDRO-M hydronic module

Note: Hydraulic module and direct expansion indoor units cannot operate at the same time.

MULTISplit

COMBINATION TABLES

Outdoor unit: MU2-Y 125M (PENTA)

COOLING	OUTDOOR UNIT	INDOOR UNIT					COOLING CAPACITY [KW]					TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	D	E	A	B	C	D	E	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
MU2-Y 125M (1x1)	20M	8.000	—	—	—	—	2,30	—	—	—	—	1,66	2,00	2,90	0,45	1,02	1,28	1,96	4,44	5,56	3,23	—	—	—	—
	27M	9.000	—	—	—	—	2,50	—	—	—	—	1,66	2,50	3,20	0,45	1,28	1,60	1,96	5,56	6,94	3,23	—	—	—	—
	35M	12.000	—	—	—	—	3,50	—	—	—	—	1,66	3,50	3,90	0,45	1,79	2,15	1,96	7,78	9,33	3,23	—	—	—	—
	53M	18.000	—	—	—	—	5,00	—	—	—	—	1,85	5,00	6,50	0,58	1,98	2,28	2,52	8,62	9,91	3,23	—	—	—	—
	70M	24.000	—	—	—	—	7,00	—	—	—	—	2,09	7,00	8,20	0,70	2,30	2,42	3,04	10,00	10,50	3,23	—	—	—	—
	20M	20M	—	—	—	—	2,10	2,10	—	—	—	2,34	4,20	7,38	0,65	1,49	2,21	2,81	6,49	9,60	3,23	A	5,10	4,20	288
	8.000	8.000	—	—	—	—	2,39	2,69	—	—	—	2,34	4,78	7,63	0,65	1,70	2,36	2,81	7,38	10,27	3,23	A	5,10	4,70	323
	20M	27M	—	—	—	—	2,38	3,57	—	—	—	2,34	5,65	8,00	0,65	2,01	2,55	2,81	8,72	11,09	3,23	A	5,10	5,50	377
	8.000	9.000	—	—	—	—	2,37	5,32	—	—	—	2,34	7,38	9,84	0,65	2,62	2,70	2,81	11,40	11,76	3,23	A	5,10	7,00	480
	20M	35M	—	—	—	—	2,34	6,98	—	—	—	2,34	9,02	11,69	0,65	3,21	3,05	2,81	13,94	13,25	3,23	A	5,10	9,10	625
MU2-Y 125M (1x2)	8.000	12.000	—	—	—	—	2,68	2,68	—	—	—	2,34	5,36	8,00	0,65	1,90	2,55	2,81	8,28	11,09	3,23	A	5,10	5,30	364
	20M	53M	—	—	—	—	2,67	3,56	—	—	—	2,34	6,23	8,61	0,65	2,21	2,59	2,81	9,62	11,26	3,23	A	5,10	6,00	412
	8.000	18.000	—	—	—	—	2,65	5,31	—	—	—	2,34	7,96	11,07	0,65	2,83	2,86	2,81	12,30	12,42	3,23	A	5,10	7,50	515
	20M	70M	—	—	—	—	2,62	6,98	—	—	—	2,34	9,60	12,30	0,65	3,41	3,24	2,81	14,83	14,07	3,23	A	5,10	9,70	666
	8.000	24.000	—	—	—	—	3,55	3,55	—	—	—	2,34	7,09	9,23	0,65	2,52	2,70	2,81	10,96	11,76	3,23	A	5,10	7,00	480
	35M	35M	—	—	—	—	3,53	5,30	—	—	—	2,34	8,83	11,69	0,65	3,14	3,12	2,81	13,64	13,58	3,23	A	5,10	8,50	583
	12.000	12.000	—	—	—	—	3,49	6,98	—	—	—	2,34	10,47	12,30	0,65	3,72	3,43	2,81	16,17	14,90	3,23	A	5,10	10,00	686
	35M	53M	—	—	—	—	5,28	5,28	—	—	—	2,34	10,56	12,30	0,65	3,75	3,43	2,81	16,32	14,90	3,23	A	5,10	10,50	721
	12.000	18.000	—	—	—	—	4,93	6,57	—	—	—	2,34	11,50	12,50	0,65	3,88	3,43	2,81	16,88	14,90	3,23	A	5,10	11,50	789
	35M	70M	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	12.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	53M	53M	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	18.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	53M	70M	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	18.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

Notes Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 125M (PENTA)

COOLING	OUTDOOR UNIT	INDOOR UNIT					COOLING CAPACITY [KW]					TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)				
							A	B	C	D	E	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEE	R	Pd	CEA [kWh]
		20M 8.000	20M 8.000	20M 8.000	—	—	2,30	2,30	2,30	—	—	2,89	6,13	7,38	0,80	1,76	3,05	3,48	7,66	13,25	3,23	A	5,30	6,00	396	
MU2-Y 125M (1x3)	20M 8.000	20M 8.000	27M 9.000	—	—	2,34	2,34	2,62	—	—	2,89	6,71	8,61	0,80	1,93	3,24	3,48	8,39	14,07	3,23	A	5,30	6,50	429		
	20M 8.000	20M 8.000	35M 12.000	—	—	2,34	2,34	3,50	—	—	2,89	7,58	9,23	0,80	2,18	3,43	3,48	9,47	14,90	3,23	A	5,30	7,50	495		
	20M 8.000	20M 8.000	53M 18.000	—	—	2,34	2,34	5,24	—	—	2,89	9,31	11,07	0,80	2,68	3,62	3,48	11,64	15,73	3,23	A	5,30	9,00	594		
	20M 8.000	20M 8.000	70M 24.000	—	—	2,32	2,32	6,92	—	—	2,89	10,95	12,92	0,80	3,15	3,81	3,48	13,69	16,56	3,23	A	5,30	11,00	726		
	20M 8.000	27M 9.000	27M 9.000	—	—	2,34	2,62	2,62	—	—	2,89	7,29	9,23	0,80	2,10	3,35	3,48	9,11	14,57	3,23	A	5,30	7,00	462		
	20M 8.000	27M 9.000	35M 12.000	—	—	2,34	2,62	3,49	—	—	2,89	8,15	10,46	0,80	2,35	3,50	3,48	10,20	15,23	3,23	A	5,30	8,00	528		
	20M 8.000	27M 9.000	53M 18.000	—	—	2,34	2,62	5,24	—	—	2,89	9,89	11,07	0,80	2,84	3,73	3,48	12,37	16,23	3,23	A	5,30	9,50	627		
	20M 8.000	27M 9.000	70M 24.000	—	—	2,32	2,59	6,92	—	—	2,89	11,53	12,92	0,80	3,32	3,96	3,48	14,42	17,22	3,23	A	5,30	11,50	759		
	20M 8.000	35M 12.000	35M 12.000	—	—	2,34	3,49	3,49	—	—	2,89	9,02	11,07	0,80	2,59	3,62	3,48	11,28	15,73	3,23	A	5,30	9,00	594		
	20M 8.000	35M 12.000	53M 18.000	—	—	2,34	3,49	5,23	—	—	2,89	10,76	12,30	0,80	3,09	3,81	3,48	13,45	16,56	3,23	A	5,30	10,50	693		
	20M 8.000	35M 12.000	70M 24.000	—	—	2,32	3,46	6,92	—	—	2,89	12,40	12,92	0,80	3,57	3,96	3,48	15,50	17,22	3,23	A	5,30	11,50	759		
	20M 8.000	53M 18.000	53M 18.000	—	—	2,33	5,23	5,23	—	—	2,89	12,49	12,92	0,80	3,59	3,96	3,48	15,62	17,22	3,23	A	5,30	11,50	759		
	27M 9.000	27M 9.000	27M 9.000	—	—	2,62	2,62	2,62	—	—	2,89	7,86	10,46	0,80	2,26	3,81	3,48	9,83	16,56	3,23	A	5,30	8,00	528		
	27M 9.000	27M 9.000	35M 12.000	—	—	2,62	2,62	3,49	—	—	2,89	8,73	12,92	0,80	2,51	3,62	3,48	10,92	15,73	3,23	A	5,30	9,00	594		
	27M 9.000	27M 9.000	53M 18.000	—	—	2,62	2,62	5,23	—	—	2,89	10,47	12,30	0,80	3,01	3,81	3,48	13,09	16,56	3,23	A	5,30	10,50	693		
	27M 9.000	27M 9.000	70M 24.000	—	—	2,59	2,59	6,92	—	—	2,89	12,11	12,92	0,80	3,48	3,96	3,48	15,14	17,22	3,23	A	5,30	11,50	759		
	27M 9.000	35M 12.000	35M 12.000	—	—	2,62	3,49	3,49	—	—	2,89	9,60	11,07	0,80	2,76	3,62	3,48	12,00	15,73	3,23	A	5,30	9,00	594		
	27M 9.000	35M 12.000	53M 18.000	—	—	2,62	3,49	5,23	—	—	2,89	11,34	11,69	0,80	3,26	3,81	3,48	14,18	16,56	3,23	A	5,30	11,00	726		
	27M 9.000	35M 12.000	70M 24.000	—	—	2,60	3,46	6,92	—	—	2,89	12,98	12,92	0,80	3,73	3,96	3,48	16,23	17,22	3,23	A	5,30	11,50	759		
	27M 9.000	53M 18.000	53M 18.000	—	—	2,61	5,23	5,23	—	—	2,89	13,07	12,92	0,80	3,76	3,96	3,48	16,35	17,22	3,23	A	5,30	12,00	792		
	35M 12.000	35M 12.000	35M 12.000	—	—	3,49	3,49	3,49	—	—	2,89	10,47	11,07	0,80	3,01	3,73	3,48	13,09	16,23	3,23	A	5,30	9,50	627		
	35M 12.000	35M 12.000	53M 18.000	—	—	3,49	3,49	5,23	—	—	2,89	12,20	12,92	0,80	3,51	3,96	3,48	15,26	17,22	3,23	A	5,30	11,50	759		
	35M 12.000	35M 12.000	70M 24.000	—	—	3,46	3,46	6,92	—	—	2,89	13,84	12,92	0,80	3,98	3,96	3,48	17,31	17,22	3,23	A	5,30	12,00	792		
	35M 12.000	53M 18.000	53M 18.000	—	—	3,48	5,23	5,23	—	—	2,89	13,94	12,92	0,80	4,01	3,96	3,48	17,43	17,22	3,23	A	5,30	12,00	792		
	35M 12.000	53M 18.000	70M 24.000	—	—	2,67	4,00	5,33	—	—	2,89	12,00	12,92	0,80	4,15	3,96	3,48	18,05	17,22	3,23	A	5,30	12,00	792		
	53M 18.000	53M 18.000	53M 18.000	—	—	4,00	4,00	4,00	—	—	2,89	12,00	12,92	0,80	4,15	3,96	3,48	18,05	17,22	3,23	A	5,30	12,00	792		

Notes Pd = Pdesign CEA = Annual Energy Consumption

MULTISPLIT

COMBINATION TABLES

Outdoor unit: MU2-Y 125M (PENTA)

MULTISplit

COOLING	OUTDOOR UNIT	INDOOR UNIT				COOLING CAPACITY [KW]					TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)				
		A	B	C	D	E	A	B	C	D	E	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.		Max.	Class	SEER	Pd	CEA [kWh]
MU2-Y 125M (1x4)	20M	20M	20M	20M	—	2,30	2,30	2,30	2,30	—	3,69	8,00	10,50	0,91	2,63	3,43	3,97	11,44	14,90	3,23	A+	5,60	8,00	500	
	8.000	8.000	8.000	8.000	—	1,98	1,98	1,98	2,55	—	3,69	8,50	11,07	0,91	2,81	3,62	3,97	12,23	15,73	3,23	A+	5,60	8,50	531	
	20M	20M	20M	27M	—	2,32	2,32	2,32	3,45	—	3,69	9,50	11,69	0,91	3,17	3,73	3,97	13,79	16,23	3,23	A+	5,60	9,50	594	
	8.000	8.000	8.000	9.000	—	2,36	2,36	2,36	5,31	—	3,69	11,50	12,30	0,91	3,91	4,19	3,97	17,00	18,21	3,23	A+	5,60	11,50	719	
	20M	20M	20M	70M	—	1,87	1,87	1,87	6,40	—	3,69	12,00	13,53	0,91	4,15	4,38	3,97	18,05	19,04	3,23	A+	5,60	12,00	750	
	8.000	8.000	8.000	24.000	—	2,38	2,38	2,67	2,67	—	3,69	9,50	11,69	0,91	3,16	3,73	3,97	13,75	16,23	3,23	A+	5,60	9,50	594	
	20M	20M	27M	35M	—	2,00	2,00	2,57	3,43	—	3,69	10,00	12,30	0,91	3,36	4,19	3,97	14,60	18,21	3,23	A+	5,60	10,00	625	
	8.000	8.000	9.000	12.000	—	1,96	1,96	2,52	5,05	—	3,69	11,50	12,30	0,91	3,93	4,19	3,97	17,11	18,21	3,23	A+	5,60	11,50	719	
	20M	20M	27M	70M	—	1,79	1,79	2,30	6,13	—	3,69	12,00	13,53	0,91	4,15	4,38	3,97	18,05	19,04	3,23	A+	5,60	12,00	750	
	8.000	8.000	9.000	24.000	—	1,93	1,93	3,32	3,32	—	3,69	10,50	12,92	0,91	3,56	4,19	3,97	15,48	18,21	3,23	A+	5,60	10,50	656	
	20M	20M	35M	53M	—	1,83	1,83	3,14	4,70	—	3,69	11,50	13,53	0,91	3,97	4,19	3,97	17,27	18,21	3,23	A+	5,60	11,50	719	
	8.000	8.000	12.000	18.000	—	1,72	1,72	2,95	5,90	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	20M	20M	35M	70M	—	1,72	1,72	4,43	4,43	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	8.000	8.000	18.000	24.000	—	1,54	1,54	3,95	5,27	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	20M	27M	27M	70M	—	2,36	2,65	2,65	2,65	—	3,69	10,00	12,30	0,91	3,35	4,19	3,97	14,56	18,21	3,23	A+	5,60	10,00	625	
	8.000	9.000	9.000	9.000	—	1,99	2,55	2,55	3,41	—	3,69	10,50	12,92	0,91	3,55	4,19	3,97	15,43	18,21	3,23	A+	5,60	10,50	656	
	20M	27M	27M	53M	—	1,87	2,41	2,41	4,81	—	3,69	11,50	13,53	0,91	3,96	4,19	3,97	17,21	18,21	3,23	A+	5,60	11,50	719	
	8.000	9.000	9.000	18.000	—	1,76	2,26	2,26	6,02	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	20M	27M	35M	35M	—	2,31	2,59	3,45	3,45	—	3,69	11,50	13,53	0,91	3,92	4,19	3,97	17,05	18,21	3,23	A+	5,60	11,50	719	
	8.000	9.000	12.000	12.000	—	1,83	2,35	3,13	4,70	—	3,69	12,00	13,53	0,91	4,15	4,38	3,97	18,05	19,04	3,23	A+	5,60	12,00	750	
	20M	27M	35M	70M	—	1,66	2,13	2,84	5,68	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	8.000	9.000	12.000	24.000	—	1,66	2,13	4,26	4,26	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	20M	27M	53M	70M	—	1,48	1,91	3,82	5,09	—	3,69	12,30	13,53	0,91	4,23	4,38	3,97	18,41	19,04	3,23	A+	5,60	12,40	775	
	8.000	9.000	18.000	24.000	—	1,87	3,21	3,21	3,21	—	3,69	11,50	13,53	0,91	3,96	4,19	3,97	17,21	18,21	3,23	A+	5,60	11,50	719	
	20M	35M	35M	53M	—	1,71	2,94	2,94	4,41	—	3,69	12,00	13,53	0,91	4,15	4,38	3,97	18,05	19,04	3,23	A+	5,60	12,00	750	
	8.000	12.000	12.000	18.000	—	1,57	2,68	2,68	5,37	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	20M	35M	35M	70M	—	1,57	2,68	4,03	4,03	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	8.000	12.000	18.000	18.000	—	2,63	2,63	2,63	2,63	—	3,69	10,50	12,92	0,91	3,54	4,19	3,97	15,38	18,21	3,23	A+	5,60	10,50	656	
	27M	27M	27M	35M	—	2,65	2,65	2,65	3,54	—	3,69	11,50	13,53	0,91	3,91	4,19	3,97	17,00	18,21	3,23	A+	5,60	11,50	719	
	9.000	9.000	9.000	12.000	—	2,40	2,40	2,40	4,80	—	3,69	12,00	13,53	0,91	4,15	4,38	3,97	18,05	19,04	3,23	A+	5,60	12,00	750	
	27M	27M	27M	70M	—	2,17	2,17	2,17	5,79	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	9.000	9.000	9.000	24.000	—	2,46	2,46	3,29	3,29	—	3,69	11,50	13,53	0,91	3,95	4,19	3,97	17,16	18,21	3,23	A+	5,60	11,50	719	
	27M	27M	35M	53M	—	2,25	2,25	3,00	4,50	—	3,69	12,00	13,53	0,91	4,15	4,38	3,97	18,05	19,04	3,23	A+	5,60	12,00	750	
	9.000	9.000	12.000	18.000	—	2,35	2,35	2,73	5,47	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	27M	27M	35M	70M	—	2,35	2,35	4,10	4,10	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	9.000	9.000	18.000	18.000	—	2,30	3,07	3,07	3,07	—	3,69	11,50	13,53	0,91	3,98	4,19	3,97	17,30	18,21	3,23	A+	5,60	11,50	719	
	27M	35M	35M	53M	—	2,17	2,89	2,89	4,34	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	9.000	12.000	12.000	18.000	—	1,94	2,59	2,59	5,18	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	27M	35M	53M	70M	—	1,94	2,59	3,88	3,88	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	9.000	12.000	18.000	18.000	—	2,88	2,88	2,88	2,88	—	3,69	11,50	13,53	0,91	3,98	4,19	3,97	17,30	18,21	3,23	A+	5,60	11,50	719	
	35M	35M	35M	53M	—	2,73	2,73	2,73	4,10	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	
	12.000	12.000	12.000	18.000	—	2,73	2,73	2,73	4,10	—	3,69	12,30	13,53	0,91	4,26	4,38	3,97	18,50	19,04	3,23	A+	5,60	12,40	775	

COOLING

COMBINATION TABLES

Outdoor unit: MU2-Y 125M (PENTA)

MULTISPLIT

OUTDOOR UNIT	INDOOR UNIT					COOLING CAPACITY [KW]					TOTAL COOLING CAPACITY [KW]			POWER INPUT COOLING [KW]			TOTAL COOLING CURRENT [A]			EER	SEASONAL EFFICIENCY (EN14825)			
	A	B	C	D	E	A	B	C	D	E	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SEER	Pd	CEA [kWh]
	20M 8.000	20M 8.000	20M 8.000	20M 8.000	20M 8.000	2,46	2,46	2,46	2,46	2,46	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
MU2-Y 125M (1x5)	20M 8.000	20M 8.000	20M 8.000	20M 8.000	27M 9.000	2,33	2,33	2,33	2,33	2,99	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	2,15	2,15	2,15	2,15	3,69	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,87	1,87	1,87	1,87	4,81	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	20M 8.000	70M 24.000	1,66	1,66	1,66	1,66	5,68	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	27M 9.000	27M 9.000	2,21	2,21	2,21	2,84	2,84	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	27M 9.000	35M 12.000	2,35	2,35	2,35	2,64	3,51	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	27M 9.000	53M 18.000	1,79	1,79	1,79	2,31	4,61	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	27M 9.000	70M 24.000	1,59	1,59	1,59	2,35	5,47	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,91	1,91	1,91	3,28	3,28	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,69	1,69	1,69	2,89	4,34	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	20M 8.000	70M 24.000	1,51	1,51	1,51	2,59	5,18	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	53M 18.000	53M 18.000	1,51	1,51	1,51	3,88	3,88	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	20M 8.000	27M 9.000	27M 9.000	2,10	2,10	2,70	2,70	2,70	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	27M 9.000	27M 9.000	35M 12.000	1,96	1,96	2,52	2,52	3,35	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	27M 9.000	27M 9.000	53M 18.000	1,72	1,72	2,21	2,21	4,43	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	27M 9.000	27M 9.000	70M 24.000	1,54	1,54	1,98	1,98	5,27	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	27M 9.000	35M 12.000	35M 12.000	1,83	1,83	2,36	3,14	3,14	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	27M 9.000	35M 12.000	53M 18.000	1,62	1,62	2,39	2,78	4,18	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	27M 9.000	53M 18.000	53M 18.000	1,46	1,46	1,88	3,75	3,75	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	35M 12.000	35M 12.000	35M 12.000	1,72	1,72	2,95	2,95	2,95	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	20M 8.000	35M 12.000	35M 12.000	53M 18.000	1,54	1,54	2,64	2,64	3,95	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	27M 9.000	27M 9.000	27M 9.000	27M 9.000	2,30	2,57	2,57	2,57	2,57	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	27M 9.000	27M 9.000	27M 9.000	35M 12.000	1,87	2,41	2,41	2,41	3,21	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	27M 9.000	27M 9.000	27M 9.000	53M 18.000	1,66	2,13	2,13	2,13	4,26	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	27M 9.000	27M 9.000	27M 9.000	70M 24.000	1,48	1,91	1,91	1,91	5,09	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	27M 9.000	27M 9.000	35M 12.000	35M 12.000	1,76	2,26	2,26	3,01	3,01	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	27M 9.000	27M 9.000	35M 12.000	53M 18.000	1,57	2,31	2,31	2,68	4,03	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	27M 9.000	35M 12.000	35M 12.000	35M 12.000	1,66	2,13	2,84	2,84	2,84	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	27M 9.000	35M 12.000	35M 12.000	53M 18.000	1,48	1,91	2,54	2,54	3,82	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	20M 8.000	35M 12.000	35M 12.000	35M 12.000	35M 12.000	1,57	2,68	2,68	2,68	2,68	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	27M 9.000	27M 9.000	27M 9.000	27M 9.000	27M 9.000	2,46	2,46	2,46	2,46	2,46	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	27M 9.000	27M 9.000	27M 9.000	27M 9.000	35M 12.000	2,31	2,31	2,31	2,31	3,08	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	27M 9.000	27M 9.000	27M 9.000	27M 9.000	53M 18.000	2,35	2,35	2,35	2,35	4,10	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	27M 9.000	27M 9.000	27M 9.000	27M 9.000	35M 12.000	2,17	2,17	2,17	2,89	2,89	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	27M 9.000	27M 9.000	27M 9.000	35M 12.000	53M 18.000	1,94	1,94	1,94	2,59	3,88	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	27M 9.000	27M 9.000	35M 12.000	35M 12.000	35M 12.000	2,35	2,35	2,73	2,73	2,73	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706
	27M 9.000	35M 12.000	35M 12.000	35M 12.000	35M 12.000	1,94	2,59	2,59	2,59	2,59	4,18	12,30	14,00	1,03	3,81	4,57	4,47	16,56	19,87	3,23	A++	6,10	12,30	706

Notes: Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 125M (PENTA)

	OUTDOOR UNIT	INDOOR UNIT					HEATING CAPACITY [KW]					TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	D	E	A	B	C	D	E	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
MULTISplit	MU2-Y 125M (1x1)	20M	—	—	—	—	2,50	—	—	—	—	1,66	2,50	2,90	0,45	0,67	0,83	1,96	2,90	3,62	3,71	—	—	—	—
		8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	—	—	—	—	3,00	—	—	—	—	1,66	3,00	3,20	0,45	0,80	1,00	1,96	3,48	4,35	3,71	—	—	—	—
		9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	—	—	—	—	3,80	—	—	—	—	1,66	3,80	3,90	0,45	1,01	1,22	1,96	4,41	5,29	3,71	—	—	—	—
		12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		53M	—	—	—	—	5,20	—	—	—	—	1,85	5,20	7,00	0,58	1,38	1,59	2,52	6,01	6,91	3,71	—	—	—	—
		18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
	MU2-Y 125M (1x2)	70M	—	—	—	—	7,20	—	—	—	—	2,09	7,20	8,50	0,70	1,90	2,00	3,04	8,28	8,70	3,71	—	—	—	—
		24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	20M	—	—	—	2,50	2,50	—	—	—	2,34	5,00	7,38	0,56	1,32	1,92	2,45	5,72	8,36	3,71	B	3,00	5,10	2380
		8.000	8.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	27M	—	—	—	2,45	3,15	—	—	—	2,34	5,60	7,63	0,56	1,47	2,06	2,45	6,41	8,94	3,71	B	3,00	5,70	2660
		8.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	35M	—	—	—	2,21	3,79	—	—	—	2,34	6,00	8,00	0,56	1,58	2,22	2,45	6,86	9,66	3,71	B	3,00	6,20	2893
		8.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	53M	—	—	—	2,24	5,76	—	—	—	2,34	8,00	9,84	0,56	2,11	2,35	2,45	9,15	10,23	3,71	B	3,00	8,10	3780
		8.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		20M	70M	—	—	—	2,21	7,59	—	—	—	2,34	9,80	11,69	0,56	2,58	2,65	2,45	11,21	11,53	3,71	B	3,00	8,50	3967
		8.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	27M	—	—	—	3,00	3,00	—	—	—	2,34	6,00	8,00	0,56	1,58	2,22	2,45	6,86	9,66	3,71	B	3,00	6,20	2893
		9.000	9.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	35M	—	—	—	2,91	3,89	—	—	—	2,34	6,80	8,61	0,56	1,79	2,25	2,45	7,78	9,80	3,71	B	3,00	6,80	3173
		9.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	53M	—	—	—	2,93	5,87	—	—	—	2,34	8,80	11,07	0,56	2,32	2,49	2,45	10,07	10,81	3,71	B	3,00	8,50	3967
		9.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		27M	70M	—	—	—	2,78	7,42	—	—	—	2,34	10,20	12,30	0,56	2,68	2,82	2,45	11,67	12,25	3,71	B	3,00	8,50	3967
		9.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	35M	—	—	—	3,75	3,75	—	—	—	2,34	7,50	9,23	0,56	1,97	2,35	2,45	8,58	10,23	3,71	B	3,00	7,30	3407
		12.000	12.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	53M	—	—	—	3,76	5,64	—	—	—	2,34	9,40	11,69	0,56	2,47	2,72	2,45	10,76	11,82	3,71	B	3,00	8,50	3967
		12.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		35M	70M	—	—	—	3,50	7,00	—	—	—	2,34	10,50	12,30	0,56	2,76	2,98	2,45	12,01	12,97	3,71	B	3,00	8,50	3967
		12.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		53M	53M	—	—	—	5,50	5,50	—	—	—	2,34	11,00	12,30	0,56	2,89	2,98	2,45	12,59	12,97	3,71	B	3,00	8,50	3967
		18.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		53M	70M	—	—	—	4,93	6,57	—	—	—	2,34	11,50	12,50	0,56	3,01	2,98	2,45	13,09	12,97	3,71	B	3,00	8,50	3967
		18.000	24.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

Notes Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 125M (PENTA)

HEATING	OUTDOOR UNIT	INDOOR UNIT					HEATING CAPACITY [KW]					TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	D	E	A	B	C	D	E	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.	Class	SCOP	Pd	CEA [kWh]	
MU2-Y 125M (1x3)		20M	20M	20M	—	—	2,50	2,50	2,50	—	—	2,89	7,50	8,61	0,70	1,95	2,65	3,03	8,47	11,53	3,71	B	3,20	7,30	3194
		8.000	8.000	8.000	—	—	2,37	2,37	3,05	—	—	2,89	7,80	9,23	0,70	2,03	2,82	3,03	8,81	12,25	3,71	B	3,20	7,40	3238
		20M	20M	27M	—	—	2,29	2,29	3,92	—	—	2,89	8,50	9,84	0,70	2,21	2,98	3,03	9,60	12,97	3,71	B	3,20	7,50	3281
		8.000	8.000	9.000	—	—	2,52	2,52	6,47	—	—	2,89	11,50	12,30	0,70	2,99	3,15	3,03	12,99	13,69	3,71	B	3,20	8,50	3719
		20M	20M	35M	—	—	2,21	2,21	7,58	—	—	2,89	12,00	12,92	0,70	3,12	3,32	3,03	13,55	14,41	3,71	B	3,20	8,50	3719
		8.000	8.000	12.000	—	—	2,38	3,06	3,06	—	—	2,89	8,50	9,84	0,70	2,21	2,92	3,03	9,60	12,68	3,71	B	3,20	7,50	3281
		20M	20M	53M	—	—	2,50	3,21	4,29	—	—	2,89	10,00	12,30	0,70	2,60	3,05	3,03	11,29	13,26	3,71	B	3,20	8,00	3500
		8.000	9.000	9.000	—	—	2,37	3,04	6,09	—	—	2,89	11,50	12,30	0,70	2,99	3,25	3,03	12,99	14,13	3,71	B	3,20	8,50	3719
		20M	27M	35M	—	—	2,10	2,70	7,20	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		8.000	9.000	12.000	—	—	2,48	4,26	4,26	—	—	2,89	11,00	12,30	0,70	2,86	3,15	3,03	12,42	13,69	3,71	B	3,20	8,50	3719
		20M	27M	27M	—	—	2,18	3,73	5,59	—	—	2,89	11,50	12,30	0,70	2,99	3,32	3,03	12,99	14,41	3,71	B	3,20	8,50	3719
		8.000	9.000	18.000	—	—	1,95	3,35	6,70	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		20M	35M	53M	—	—	1,95	5,02	5,02	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		8.000	12.000	18.000	—	—	3,33	3,33	3,33	—	—	2,89	10,00	12,30	0,70	2,60	3,32	3,03	11,29	14,41	3,71	B	3,20	8,50	3719
		20M	35M	70M	—	—	3,30	3,30	4,40	—	—	2,89	11,00	12,30	0,70	2,86	3,15	3,03	12,42	13,69	3,71	B	3,20	8,50	3719
		8.000	9.000	12.000	—	—	2,88	2,88	5,75	—	—	2,89	11,50	12,30	0,70	2,99	3,32	3,03	12,99	14,41	3,71	B	3,20	8,50	3719
		20M	27M	70M	—	—	2,57	2,57	6,86	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		8.000	9.000	24.000	—	—	3,14	4,18	4,18	—	—	2,89	11,50	12,30	0,70	2,99	3,15	3,03	12,99	13,69	3,71	B	3,20	8,50	3719
		20M	35M	53M	—	—	2,77	3,69	5,54	—	—	2,89	12,00	12,92	0,70	3,12	3,32	3,03	13,55	14,41	3,71	B	3,20	8,50	3719
		8.000	12.000	18.000	—	—	2,40	3,20	6,40	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		20M	35M	70M	—	—	2,40	4,80	4,80	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		8.000	9.000	18.000	—	—	3,83	3,83	3,83	—	—	2,89	11,50	12,30	0,70	2,99	3,25	3,03	12,99	14,13	3,71	B	3,20	8,50	3719
		20M	35M	53M	—	—	3,43	3,43	5,14	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		8.000	12.000	24.000	—	—	3,00	3,00	6,00	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		20M	53M	53M	—	—	3,00	4,50	4,50	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		8.000	18.000	18.000	—	—	2,67	4,00	5,33	—	—	2,89	12,00	12,92	0,70	3,12	3,45	3,03	13,55	14,99	3,71	B	3,20	8,50	3719
		20M	53M	53M	—	—	4,00	4,00	4,00	—	—	2,89	12,00	12,92	0,70	3,09	3,45	3,03	13,45	14,99	3,71	B	3,20	8,50	3719
		8.000	18.000	18.000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—

Notes Pd = Pdesign CEA = Annual Energy Consumption

MULTISPLIT

COMBINATION TABLES

Outdoor unit: MU2-Y 125M (PENTA)

MULTISplit	OUTDOOR UNIT	INDOOR UNIT					HEATING CAPACITY [kW]					TOTAL HEATING CAPACITY [kW]			ABSORBED HEATING CAPACITY [kW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	D	E	A	B	C	D	E	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	—	2,50	2,50	2,50	2,50	—	3,69	10,00	12,67	0,80	2,56	2,98	3,46	11,12	12,97	3,71	A	3,40	8,80	3624
MU2-Y 125M (1x4)		20M 8.000	20M 8.000	20M 8.000	27M 9.000	—	2,57	2,57	2,57	3,30	—	3,69	11,00	12,92	0,80	2,81	3,15	3,46	12,23	13,69	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	20M 8.000	35M 12.000	—	2,50	2,50	2,50	4,29	—	3,69	11,80	13,53	0,80	3,02	3,25	3,46	13,12	14,13	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	20M 8.000	53M 18.000	—	2,15	2,15	2,15	5,54	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	20M 8.000	70M 24.000	—	1,91	1,91	1,91	6,56	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	27M 9.000	27M 9.000	—	2,63	2,63	3,38	3,38	—	3,69	12,00	13,53	0,80	3,07	3,25	3,46	13,34	14,13	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	27M 9.000	35M 12.000	—	2,40	2,40	3,09	4,11	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	27M 9.000	53M 18.000	—	2,35	2,35	2,63	5,27	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	27M 9.000	70M 24.000	—	1,83	1,83	2,36	6,28	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	35M 12.000	35M 12.000	—	2,21	2,21	3,79	3,79	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	35M 12.000	53M 18.000	—	1,91	1,91	3,27	4,91	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	35M 12.000	70M 24.000	—	1,72	1,72	2,95	5,90	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	53M 18.000	53M 18.000	—	1,68	1,68	4,32	4,32	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	20M 8.000	53M 18.000	70M 24.000	—	1,54	1,54	3,95	5,27	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	27M 9.000	27M 9.000	27M 9.000	—	2,47	3,18	3,18	3,18	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	27M 9.000	27M 9.000	35M 12.000	—	2,27	2,92	2,92	3,89	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	27M 9.000	27M 9.000	53M 18.000	—	1,95	2,51	2,51	5,02	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	27M 9.000	27M 9.000	70M 24.000	—	1,76	2,26	2,26	6,02	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	27M 9.000	35M 12.000	35M 12.000	—	2,10	2,70	3,60	3,60	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	27M 9.000	35M 12.000	53M 18.000	—	1,83	2,35	3,13	4,70	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	27M 9.000	35M 12.000	70M 24.000	—	1,66	2,13	2,84	5,68	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	27M 9.000	53M 18.000	53M 18.000	—	1,62	2,38	4,15	4,15	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	27M 9.000	53M 18.000	70M 24.000	—	1,48	1,91	3,82	5,09	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	35M 12.000	35M 12.000	35M 12.000	—	1,95	3,35	3,35	3,35	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		20M 8.000	35M 12.000	35M 12.000	53M 18.000	—	1,71	2,94	2,94	4,41	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	35M 12.000	35M 12.000	70M 24.000	—	1,57	2,68	2,68	5,37	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		20M 8.000	35M 12.000	53M 18.000	53M 18.000	—	1,53	2,62	3,93	3,93	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		27M 9.000	27M 9.000	27M 9.000	27M 9.000	—	3,00	3,00	3,00	3,00	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		27M 9.000	27M 9.000	27M 9.000	35M 12.000	—	2,77	2,77	2,77	3,69	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		27M 9.000	27M 9.000	27M 9.000	53M 18.000	—	2,40	2,40	2,40	4,80	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		27M 9.000	27M 9.000	27M 9.000	70M 24.000	—	2,17	2,17	2,17	5,79	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		27M 9.000	27M 9.000	35M 12.000	35M 12.000	—	2,57	2,57	3,43	3,43	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		27M 9.000	27M 9.000	35M 12.000	53M 18.000	—	2,25	2,25	3,00	4,50	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		27M 9.000	27M 9.000	35M 12.000	70M 24.000	—	2,35	2,35	2,73	5,47	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		27M 9.000	27M 9.000	53M 18.000	53M 18.000	—	2,00	2,00	4,00	4,00	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		27M 9.000	35M 12.000	35M 12.000	35M 12.000	—	2,40	3,20	3,20	3,20	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		27M 9.000	35M 12.000	35M 12.000	53M 18.000	—	2,12	2,82	2,82	4,24	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		27M 9.000	35M 12.000	35M 12.000	70M 24.000	—	1,94	2,59	2,59	5,18	—	3,69	12,30	13,53	0,80	3,15	3,81	3,46	13,68	16,58	3,71	A	3,40	8,80	3624
		27M 9.000	35M 12.000	53M 18.000	53M 18.000	—	1,89	2,53	3,79	3,79	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624
		35M 12.000	35M 12.000	35M 12.000	35M 12.000	—	3,00	3,00	3,00	3,00	—	3,69	12,00	13,53	0,80	3,07	3,65	3,46	13,34	15,86	3,71	A	3,40	8,80	3624
		35M 12.000	35M 12.000	35M 12.000	53M 18.000	—	2,67	2,67	2,67	4,00	—	3,69	12,00	13,53	0,80	3,07	3,81	3,46	13,34	16,58	3,71	A	3,40	8,80	3624

Notes Pd = Pdesign CEA = Annual Energy Consumption

COMBINATION TABLES

Outdoor unit: MU2-Y 125M (PENTA)

HEATING	OUTDOOR UNIT	INDOOR UNIT					HEATING CAPACITY [KW]					TOTAL HEATING CAPACITY [KW]			ABSORBED HEATING CAPACITY [KW]			TOTAL COOLING CURRENT [A]			COP	SEASONAL EFFICIENCY (EN14825)			
		A	B	C	D	E	A	B	C	D	E	Min.	Std.	Max.	Min.	Std.	Max.	Min.	Std.	Max.		Class	SCOP	Pd	CEA [kWh]
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	20M 8.000	2,46	2,46	2,46	2,46	2,46	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
MU2-Y 125M (1x5)		20M 8.000	20M 8.000	20M 8.000	20M 8.000	27M 9.000	2,33	2,33	2,33	2,33	2,99	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	2,15	2,15	2,15	2,15	3,69	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,87	1,87	1,87	1,87	4,81	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	70M 24.000	1,66	1,66	1,66	1,66	5,68	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	27M 9.000	2,21	2,21	2,21	2,84	2,84	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	2,35	2,35	2,35	2,64	3,51	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,79	1,79	1,79	2,31	4,61	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	70M 24.000	1,59	1,59	1,59	2,35	5,47	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,91	1,91	1,91	3,28	3,28	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,69	1,69	1,69	2,89	4,34	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,51	1,51	1,51	2,59	5,18	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,51	1,51	1,51	3,88	3,88	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	27M 9.000	2,10	2,10	2,70	2,70	2,70	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,96	1,96	2,52	2,52	3,35	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,72	1,72	2,21	2,21	4,43	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	70M 24.000	1,54	1,54	1,98	1,98	5,27	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,83	1,83	2,36	3,14	3,14	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,62	1,62	2,39	2,78	4,18	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,46	1,46	1,88	3,75	3,75	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,72	1,72	2,95	2,95	2,95	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,54	1,54	2,64	2,64	3,95	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	27M 9.000	2,30	2,57	2,57	2,57	2,57	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,87	2,41	2,41	2,41	3,21	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,66	2,13	2,13	2,13	4,26	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	70M 24.000	1,48	1,91	1,91	1,91	5,09	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,76	2,26	2,26	3,01	3,01	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,57	2,31	2,31	2,68	4,03	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,66	2,13	2,84	2,84	2,84	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	53M 18.000	1,48	1,91	2,54	2,54	3,82	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		20M 8.000	20M 8.000	20M 8.000	20M 8.000	35M 12.000	1,57	2,68	2,68	2,68	2,68	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		27M 9.000	27M 9.000	27M 9.000	27M 9.000	27M 9.000	2,46	2,46	2,46	2,46	2,46	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		27M 9.000	27M 9.000	27M 9.000	27M 9.000	35M 12.000	2,31	2,31	2,31	2,31	3,08	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		27M 9.000	27M 9.000	27M 9.000	27M 9.000	53M 18.000	2,35	2,35	2,35	2,35	4,10	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		27M 9.000	27M 9.000	27M 9.000	27M 9.000	35M 12.000	2,17	2,17	2,17	2,89	2,89	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		27M 9.000	27M 9.000	27M 9.000	27M 9.000	53M 18.000	1,94	1,94	1,94	2,59	3,88	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		27M 9.000	27M 9.000	27M 9.000	27M 9.000	35M 12.000	2,35	2,35	2,73	2,73	2,73	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611
		27M 9.000	27M 9.000	27M 9.000	27M 9.000	35M 12.000	1,94	2,59	2,59	2,59	2,59	4,18	12,30	14,94	0,90	3,32	4,14	3,89	14,41	18,02	3,71	A	3,80	9,80	3611

Notes Pd = Pdesign CEA = Annual Energy Consumption